


OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id

KAESER SK 15 5149557 (S/N 1661)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

		Aug201	6 Apr2018	Oct2019 De	c2023	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011588	KCP20898	KCP07111
Sample Date		Client Info		28 Dec 2023	11 Oct 2019	02 Apr 2018
Machine Age	hrs	Client Info		11736	7981	6133
Oil Age	hrs	Client Info		0	1800	2935
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	13	2	5
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			6	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	2
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	1
Magnesium	ppm	ASTM D5185m	100	21	61	50
Calcium	ppm	ASTM D5185m	0	3	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	3	45
Zinc	ppm	ASTM D5185m	0	78	39	12
Sulfur	ppm	ASTM D5185m	23500	16518	17186	22105
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<1	<1
Sodium	ppm	ASTM D5185m		1	15	17
Potassium	ppm	ASTM D5185m	>20	<1	9	2
Water	%	ASTM D6304	>0.05	△ 0.090	0.023	0.008
ppm Water	ppm	ASTM D6304	>500	4 900	237.4	80
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			10231	3347
Particles >6µm		ASTM D7647	>1300		1999	1146
Particles >14μm		ASTM D7647	>80		47	29
Particles >21μm		ASTM D7647	>20		22	7
Particles >38µm		ASTM D7647	>4		6	0
Particles >71μm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>17/13		1 8/13	17/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2


0.376


0.346





OIL ANALYSIS REPORT















Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KCPA011588 : 06064357 : 10835739

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 18 Jan 2024 Diagnosed

: 21 Jan 2024 Diagnostician : Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

315 HURRICANE SHOALS RD NE LAWRENCEVILLE, GA US 30046

CAPITAL CITY GLASS

Contact: RODNEY RODNEY@CAPITALCITYGLASS.COM

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: