


OIL ANALYSIS REPORT

Sample Rating Trend



ISO



KAESER 6665854

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2022	Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011734	KCP47061	
Sample Date		Client Info		09 Jan 2024	01 Dec 2022	
Machine Age	hrs	Client Info		6608	5423	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm		>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m		<1	2	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm		>50	<1	2	
Tin		ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m	>10	0	0	
Cadmium	ppm	ASTM D5185m		0	0	
	ppm	A9 IIVI D3 I03III		U	U	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	19	22	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	80	50	
Calcium	ppm	ASTM D5185m	0	3	0	
Phosphorus	ppm	ASTM D5185m	0	0	9	
Zinc	ppm	ASTM D5185m	0	0	9	
Sulfur	ppm	ASTM D5185m	23500	18885	22139	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	5	7	
Sodium	ppm	ASTM D5185m		14	13	
Potassium	ppm	ASTM D5185m	>20	2	<1	
Water	%	ASTM D6304	>0.05	0.039	0.019	
ppm Water	ppm	ASTM D6304	>500	391	194.7	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		25332	2669	
Particles >6µm		ASTM D7647	>1300	A 8834	758	
Particles >14µm		ASTM D7647	>80	A 899	61	
Particles >21µm		ASTM D7647	>20	^ 205	12	
Particles >38µm		ASTM D7647	>4	<u>^</u> 6	2	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/20/17</u>	19/17/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.44	0.43	



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: KCPA011734 : 06064367

: 10835749

Recieved : 18 Jan 2024 Diagnosed

: 19 Jan 2024 Diagnostician : Doug Bogart

MATHER, CA US 95655 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

3678 LEMAY ST