




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**[604063006 SDR]**  
 Machine Id  
**COLD WATER PUMP 1 (S/N 20075332)**  
 Component  
**Primary Pump**  
 Fluid  
**MOBIL DTE OIL HVY MEDIUM (--- GAL)**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

Confirm oil type. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2 |
|---------------|-------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info |             | <b>WC0854253</b>   | WC0605520   | ---      |
| Sample Date   | Client Info |             | <b>28 Dec 2023</b> | 22 Jun 2023 | ---      |
| Machine Age   | mls         | Client Info | <b>0</b>           | 0           | ---      |
| Oil Age       | mls         | Client Info | <b>0</b>           | 0           | ---      |
| Oil Changed   | Client Info |             | <b>Changed</b>     | Changed     | ---      |
| Sample Status |             |             | <b>NORMAL</b>      | ATTENTION   | ---      |

## CONTAMINATION

|       | method    | limit/base | current    | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >.1        | <b>NEG</b> | NEG      | ---      |

## WEAR METALS

|          | method | limit/base  | current | history1 | history2 |     |
|----------|--------|-------------|---------|----------|----------|-----|
| Iron     | ppm    | ASTM D5185m | >90     | <b>0</b> | 0        | --- |
| Chromium | ppm    | ASTM D5185m | >5      | <b>0</b> | 0        | --- |
| Nickel   | ppm    | ASTM D5185m | >5      | <b>0</b> | 0        | --- |
| Titanium | ppm    | ASTM D5185m | >3      | <b>0</b> | <1       | --- |
| Silver   | ppm    | ASTM D5185m | >3      | <b>0</b> | 0        | --- |
| Aluminum | ppm    | ASTM D5185m | >7      | <b>0</b> | 1        | --- |
| Lead     | ppm    | ASTM D5185m | >12     | <b>0</b> | 0        | --- |
| Copper   | ppm    | ASTM D5185m | >30     | <b>0</b> | 0        | --- |
| Tin      | ppm    | ASTM D5185m | >9      | <b>0</b> | 0        | --- |
| Vanadium | ppm    | ASTM D5185m |         | <b>0</b> | 0        | --- |
| Cadmium  | ppm    | ASTM D5185m |         | <b>0</b> | 0        | --- |

## ADDITIVES

|            | method | limit/base  | current | history1   | history2 |     |
|------------|--------|-------------|---------|------------|----------|-----|
| Boron      | ppm    | ASTM D5185m |         | <b>0</b>   | 0        | --- |
| Barium     | ppm    | ASTM D5185m |         | <b>0</b>   | 0        | --- |
| Molybdenum | ppm    | ASTM D5185m |         | <b>0</b>   | 0        | --- |
| Manganese  | ppm    | ASTM D5185m |         | <b>0</b>   | 0        | --- |
| Magnesium  | ppm    | ASTM D5185m |         | <b>0</b>   | <1       | --- |
| Calcium    | ppm    | ASTM D5185m |         | <b>0</b>   | 0        | --- |
| Phosphorus | ppm    | ASTM D5185m |         | <b>10</b>  | 12       | --- |
| Zinc       | ppm    | ASTM D5185m |         | <b>0</b>   | <1       | --- |
| Sulfur     | ppm    | ASTM D5185m |         | <b>531</b> | 692      | --- |

## CONTAMINANTS


|           | method | limit/base  | current | history1     | history2 |     |
|-----------|--------|-------------|---------|--------------|----------|-----|
| Silicon   | ppm    | ASTM D5185m | >60     | <b>0</b>     | <1       | --- |
| Sodium    | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | --- |
| Potassium | ppm    | ASTM D5185m | >20     | <b>&lt;1</b> | <1       | --- |

## FLUID DEGRADATION

|                  | method   | limit/base | current | history1    | history2 |     |
|------------------|----------|------------|---------|-------------|----------|-----|
| Acid Number (AN) | mg KOH/g | ASTM D8045 |         | <b>0.09</b> | 0.094    | --- |



# OIL ANALYSIS REPORT







| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | ---      |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | ---      |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | ---      |
| Silt             | scalar | *Visual    | NONE    | NONE     | ---      |
| Debris           | scalar | *Visual    | NONE    | NONE     | ---      |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | ---      |
| Appearance       | scalar | *Visual    | NORML   | NORML    | ---      |
| Odor             | scalar | *Visual    | NORML   | NORML    | ---      |
| Emulsified Water | scalar | *Visual    | >.1     | NEG      | ---      |
| Free Water       | scalar | *Visual    |         | NEG      | ---      |

| FLUID PROPERTIES | method | limit/base | current | history1   | history2 |     |
|------------------|--------|------------|---------|------------|----------|-----|
| Visc @ 40°C      | cSt    | ASTM D445  | 65.1    | <b>104</b> | ▲ 97.7   | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

|        |  |  |  |  |  |          |
|--------|--|--|--|--|--|----------|
| Color  |  |  |  |  |  | no image |
| Bottom |  |  |  |  |  | no image |

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0854253 **Recieved** : 18 Jan 2024  
**Lab Number** : **06064446** **Diagnosed** : 21 Jan 2024  
**Unique Number** : 10835828 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**MARS CHOCOLATE**  
 2019 NORTH OAK PARK  
 CHICAGO, IL  
 US 60707  
 Contact: TONY FIORE  
 tony.fiore@effem.com  
 T: (773)745-2279  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)