

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area [604063005 SDR] Machine Id BRINE DIS PUMP 4 (S/N 20049415) Component

Pump Fluid

MOBIL DTE OIL HVY MEDIUM (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


Confirm oil type. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2023	Dec2023		
SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0854248	WC0605514	
Sample Date		Client Info		28 Dec 2023	22 Jun 2023	
Machine Age	mls	Client Info		0	0	
Oil Age	mls	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ATTENTION	
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	0	<1	
Chromium	ppm	ASTM D5185m	>5	0	0	
Nickel	ppm	ASTM D5185m	>5	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>3	0	0	
Aluminum	ppm	ASTM D5185m	>7	0	1	
Lead	ppm	ASTM D5185m	>12	0	1	
Copper	ppm	ASTM D5185m	>30	0	<1	
Tin	ppm	ASTM D5185m	>9	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	<1	
Calcium	ppm	ASTM D5185m		0	3	
Phosphorus	ppm	ASTM D5185m		10	19	
Zinc	ppm	ASTM D5185m		0	7	
Sulfur	ppm	ASTM D5185m		554	768	
CONTAMINANTS	i i	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	0	<1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.088	0.093	



OIL ANALYSIS REPORT

VISUAL



Sam Lab	nple No. Number	: WearCheck USA - : WC0854248 : 06064450 : 10835832	501 Madis Recieved Diagnose Diagnost	l :18. ed :21.	Dec28/23	Jun22/23		CHOCOLATE TH OAK PARK CHICAGO, IL US 60707
	(40°C)	90 80 70 Base 60 Abnormal 60 Abnormal			(0,10 (0,10) (0,10) (0,00) (0,			
	1	Uiscosity @ 40°C	2		Dec28/23	Acid Number	r	
	Edd	0 - lead						
		Non-ferrous Meta	als		Dec2			
		2			Dec28/23			
	E	Ferrous Alloys						
		GRAPHS						
		Bottom						no image
	Dec28/23	Color						no image
		Visc @ 40°C SAMPLE IMAGE	cSt ES	ASTM D445 method	65.1 limit/base	98.5 current	▲ 92.9 history1	 history2
		FLUID PROPER		method	limit/base	current	history1	history2
С		Emulsified Water Free Water	scalar scalar	*Visual *Visual	>.1	NEG NEG	NEG NEG	
	Dec28/23	Appearance Odor	scalar scalar	*Visual *Visual	NORML		NORML NORML	
	23	Debris Sand/Dirt	scalar scalar	*Visual *Visual	NONE NORMI	NONE	NONE NONE	
		Precipitate Silt	scalar scalar	*Visual *Visual	NONE	NONE	NONE NONE	
		Yellow Metal	scalar	*Visual	NONE	NONE	NONE	

Ē

Ē

Contact/Location: TONY FIORE - MARSCHI