




PROBLEM SUMMARY

Sample Rating Trend





WEAR



Area
LFC-1030-CM-01-CM023
 Machine Id
P201SH02-1030 - SURGE HOPPER AGITATOR #1 DRIVE
 Component
Transmission
 Fluid
LE 4220 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the fluid from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	NORMAL
Iron	ppm	ASTM D5185m	>200	🔴 491	🟡 263	51
Water	%	ASTM D6304	>0.1	🔴 2.70	🔴 1.09	---
ppm Water	ppm	ASTM D6304	>1000	🔴 27000	🔴 10900	---
Emulsified Water	scalar	*Visual	>0.1	🔴 0.2%	🔴 0.2%	NEG

Customer Id: LEPALL
 Sample No.: WC0882097
 Lab Number: 06064479
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Fluid	---	---	?	We recommend that you drain the fluid from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

09 Jan 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend that you drain the fluid and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. Gear wear is indicated. Appearance is milky. There is a high concentration of water present in the fluid. The AN level is acceptable for this fluid. The fluid is no longer serviceable due to the presence of contaminants.

view report



14 Jul 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



16 Jan 2020 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. Gear wear is indicated. Appearance is milky. There is a light concentration of water present in the fluid. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
LFC-1030-CM-01-CM023
 Machine Id
P201SH02-1030 - SURGE HOPPER AGITATOR #1 DRIVE
 Component
Transmission
 Fluid
LE 4220 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend that you drain the fluid from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

Gear wear is indicated.

Contamination

There is a high concentration of water present in the fluid.

Fluid Condition

The AN level is acceptable for this fluid. The fluid is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0882097	WC0767407	WC0587048
Sample Date	Client Info		12 Jan 2024	09 Jan 2023	14 Jul 2021
Machine Age	hrs	Client Info	60	0	0
Oil Age	hrs	Client Info	60	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	491	263	51
Chromium	ppm	ASTM D5185m >10	5	3	<1
Nickel	ppm	ASTM D5185m	3	2	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >50	1	1	0
Lead	ppm	ASTM D5185m >50	<1	<1	<1
Copper	ppm	ASTM D5185m >200	4	2	<1
Tin	ppm	ASTM D5185m >10	1	<1	<1
Antimony	ppm	ASTM D5185m	---	---	<1
Vanadium	ppm	ASTM D5185m	0	<1	<1
Cadmium	ppm	ASTM D5185m	<1	<1	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	0	1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	<1
Manganese	ppm	ASTM D5185m	4	2	<1
Magnesium	ppm	ASTM D5185m	2	0	1
Calcium	ppm	ASTM D5185m	6	0	0
Phosphorus	ppm	ASTM D5185m	422	419	407
Zinc	ppm	ASTM D5185m	13	12	9
Sulfur	ppm	ASTM D5185m	1248	1580	1041

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	17	8	5
Sodium	ppm	ASTM D5185m	25	7	0
Potassium	ppm	ASTM D5185m >20	3	2	2
Water	%	ASTM D6304 >0.1	2.70	1.09	---
ppm Water	ppm	ASTM D6304 >1000	27000	10900	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.63	0.67	0.607




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	● 0.2%	NEG
Free Water	scalar	*Visual		● NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	249	243	227

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0882097 Recieved : 18 Jan 2024
 Lab Number : 06064479 Diagnosed : 21 Jan 2024
 Unique Number : 10835861 Diagnostician : Don Baldrige

LEPRINO FOODS - ALLENDALE
 4700 RICH STREET
 ALLENDALE, MI
 US 49401
 Contact: BILL FERRIER
 BFERRIER@LEPRINOFOODS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: