




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
Ariel JGE/4 McClave compressor (S/N JG compressor)
 Component
2 Compressor
 Fluid
LO-ASH ENGINE OIL SAE 40 (55 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KL0013067	KL0011511	KL0011962
Sample Date	Client Info			11 Jan 2024	02 Nov 2023	06 Sep 2023
Machine Age	hrs	Client Info		85274	82300	82300
Oil Age	hrs	Client Info		85274	83732	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	1	<1
Lead	ppm	ASTM D5185m	>25	<1	0	<1
Copper	ppm	ASTM D5185m	>50	<1	0	1
Tin	ppm	ASTM D5185m	>15	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	37	5	8	6
Barium	ppm	ASTM D5185m	12	<1	0	0
Molybdenum	ppm	ASTM D5185m	200	3	8	49
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	5	17	17	17
Calcium	ppm	ASTM D5185m	1600	1200	1356	1337
Phosphorus	ppm	ASTM D5185m	300	328	344	310
Zinc	ppm	ASTM D5185m	400	319	424	368
Sulfur	ppm	ASTM D5185m	2600	2617	2856	2909





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	3
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	1	1	2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8511	---	5997
Particles >6µm		ASTM D7647	>2500	1036	---	787
Particles >14µm		ASTM D7647	>320	38	---	36
Particles >21µm		ASTM D7647	>80	11	---	13
Particles >38µm		ASTM D7647	>20	1	---	7
Particles >71µm		ASTM D7647	>4	0	---	2
Oil Cleanliness		ISO 4406 (c)	>18/15	17/12	---	17/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.465	---	0.19




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 138	115	113	115

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0013067 **Received** : 18 Jan 2024
Lab Number : 06065010 **Diagnosed** : 22 Jan 2024
Unique Number : 10836392 **Diagnostician** : Don Baldrige
Test Package : MOB 2 (Additional Tests: PrtCount)

STRACHAN EXPLORATION
 383 INVERNESS PKWY SUITE 360
 ENGLEWOOD, CO
 US 80112
 Contact: DENNIS JACKSON

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)