




OIL ANALYSIS REPORT



Machine Id
CATERPILLAR 3512 ULB McClave compressor (S/N 7NJ00728)
 Component
Natural Gas Engine
 Fluid
LO-ASH ENGINE OIL SAE 40 (86 GAL)

Sample Rating Trend



NORMAL



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0013068	KL0013065	KL0011510
Sample Date	Client Info		11 Jan 2024	05 Dec 2023	02 Nov 2023
Machine Age	hrs	Client Info	85274	84502	83732
Oil Age	hrs	Client Info	85274	84502	83732
Oil Changed	Client Info		Filtered	Filtered	Filtered
Sample Status			NORMAL	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	11	<1	2
Chromium	ppm	ASTM D5185m >4	<1	0	<1
Nickel	ppm	ASTM D5185m >2	0	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	2	<1	2
Lead	ppm	ASTM D5185m >30	<1	0	0
Copper	ppm	ASTM D5185m >35	2	0	<1
Tin	ppm	ASTM D5185m >4	<1	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 37	3	3	<1
Barium	ppm	ASTM D5185m 12	1	0	0
Molybdenum	ppm	ASTM D5185m 200	17	19	25
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m 5	19	20	28
Calcium	ppm	ASTM D5185m 1600	1271	1481	1395
Phosphorus	ppm	ASTM D5185m 300	351	324	312
Zinc	ppm	ASTM D5185m 400	361	407	403
Sulfur	ppm	ASTM D5185m 2600	3674	3450	2959

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	4	2	2
Sodium	ppm	ASTM D5185m	<1	0	0
Potassium	ppm	ASTM D5185m >20	2	0	2

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624 >20	5.1	5.2	5.0
Sulfation	Abs.1mm	*ASTM D7415 >30	19.8	18.5	16.9



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	2401	▲ 20409	---
Particles >6µm	ASTM D7647	>5000	1308	▲ 11118	---
Particles >14µm	ASTM D7647	>640	223	▲ 1892	---
Particles >21µm	ASTM D7647	>160	75	▲ 637	---
Particles >38µm	ASTM D7647	>40	12	▲ 98	---
Particles >71µm	ASTM D7647	>10	1	▲ 10	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	18/18/15	▲ 22/21/18	---

FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	*ASTM D7414	>25	13.4	12.9	11.3
Acid Number (AN)	mg KOH/g	ASTM D8045	1.53	1.54	---	
Base Number (BN)	mg KOH/g	ASTM D2896	3.0	3.34	1.6	

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.4	13.1	13.2	13.0

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0013068 **Received** : 18 Jan 2024
Lab Number : **06065107** **Diagnosed** : 22 Jan 2024
Unique Number : 10836489 **Diagnostician** : Wes Davis
Test Package : MOB 2 (Additional Tests: PrtCount)

STRACHAN EXPLORATION
 383 INVERNESS PKWY SUITE 360
 ENGLEWOOD, CO
 US 80112
 Contact: DENNIS JACKSON

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: