



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
NOT GIVEN WC0813954

Component
Hydraulic System

Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0813954	---	---
Sample Date	Client Info	18 Jan 2024	---	---
Machine Age	hrs	Client Info	0	---
Oil Age	hrs	Client Info	0	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ABNORMAL	---	---

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	---

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>20	0	---
Chromium	ppm	ASTM D5185m	>10	0	---
Nickel	ppm	ASTM D5185m	>10	0	---
Titanium	ppm	ASTM D5185m		0	---
Silver	ppm	ASTM D5185m		0	---
Aluminum	ppm	ASTM D5185m	>10	0	---
Lead	ppm	ASTM D5185m	>10	0	---
Copper	ppm	ASTM D5185m	>75	2	---
Tin	ppm	ASTM D5185m	>10	0	---
Vanadium	ppm	ASTM D5185m		0	---
Cadmium	ppm	ASTM D5185m		0	---

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	---
Barium	ppm	ASTM D5185m		0	---
Molybdenum	ppm	ASTM D5185m		0	---
Manganese	ppm	ASTM D5185m		<1	---
Magnesium	ppm	ASTM D5185m		8	---
Calcium	ppm	ASTM D5185m		67	---
Phosphorus	ppm	ASTM D5185m		334	---
Zinc	ppm	ASTM D5185m		429	---
Sulfur	ppm	ASTM D5185m		1077	---

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>20	0	---
Sodium	ppm	ASTM D5185m		0	---
Potassium	ppm	ASTM D5185m	>20	0	---

FLUID CLEANLINESS





method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 10565	---
Particles >6µm	ASTM D7647	>1300	▲ 1599	---
Particles >14µm	ASTM D7647	>160	120	---
Particles >21µm	ASTM D7647	>40	33	---
Particles >38µm	ASTM D7647	>10	1	---
Particles >71µm	ASTM D7647	>3	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 21/18/14	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.25	---



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	31.8	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0813954 **Received** : 19 Jan 2024
Lab Number : 06065557 **Diagnosed** : 23 Jan 2024
Unique Number : 10836939 **Diagnostician** : Don Baldrige
Test Package : CONST

PALFINGER - BRANCH 410
 632 CEDAR SWAMP RD
 JACKSON, NJ
 US 08527
 Contact: ANTHONY HARTIGAN
 a.hartigan@palfinger.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)