


# **OIL ANALYSIS REPORT**



ISO



 $^{\text{Machine Id}}$ 8795951 (S/N 1231)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Dec2023		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC108354		
Sample Date		Client Info		18 Dec 2023		
Machine Age	hrs	Client Info		2850		
Oil Age	hrs	Client Info		2850		
Oil Changed	1110	Client Info		Changed		
Sample Status		Oliciti IIIIo		ATTENTION		
			11 11 11			
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	4		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	<1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	90	53		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		11		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<1		
Sodium	ppm	ASTM D5185m		11		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304		0.015		
ppm Water	ppm	ASTM D6304		151		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5679		
Particles >6µm		ASTM D7647	>1300	<b>1705</b>		
Particles >14µm		ASTM D7647	>80	63		
Particles >21µm		ASTM D7647	>20	13		
Particles >38µm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>2</b> 0/18/13		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.27



# **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC108354 : 06065604 : 10836986

Recieved Diagnosed : 22 Jan 2024

: Don Baldridge Diagnostician

64 MARBLEDALE RD TUCKAHOE, NY US 10707

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: