




# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**KAESER BSD 60T 5994731 (S/N 4124)**

Component  
**Compressor**  
Fluid  
**FG ELITE (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC127461</b>	KC94199	KC81705
Sample Date	Client Info	<b>09 Jan 2024</b>	08 Oct 2020	27 Aug 2020
Machine Age	hrs	<b>20049</b>	13223	12798
Oil Age	hrs	<b>0</b>	2055	58
Oil Changed	Client Info	<b>N/A</b>	Changed	Not Changed
Sample Status		<b>ABNORMAL</b>	ATTENTION	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<b>0</b>	<1	<1
Chromium ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel ppm	ASTM D5185m >3	<b>0</b>	<1	<1
Titanium ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Lead ppm	ASTM D5185m >10	<b>0</b>	0	<1
Copper ppm	ASTM D5185m >50	<b>2</b>	5	4
Tin ppm	ASTM D5185m >10	<b>0</b>	<1	0
Antimony ppm	ASTM D5185m	<b>---</b>	<1	<1
Vanadium ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	<b>0</b>	12	1
Barium ppm	ASTM D5185m	<b>0</b>	0	<1
Molybdenum ppm	ASTM D5185m	<b>0</b>	0	0
Manganese ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium ppm	ASTM D5185m	<b>0</b>	50	46
Calcium ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Phosphorus ppm	ASTM D5185m	<b>32</b>	2	1
Zinc ppm	ASTM D5185m	<b>36</b>	10	5

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<b>&lt;1</b>	0	<1
Sodium ppm	ASTM D5185m	<b>0</b>	22	10
Potassium ppm	ASTM D5185m >20	<b>0</b>	5	4
Water %	ASTM D6304 >0.05	<b>0.010</b>	0.019	▲ 0.276
ppm Water	ASTM D6304 >500	<b>110</b>	198.2	▲ 2760

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>4545</b>	2008	---
Particles >6µm	ASTM D7647 >1300	▲ <b>1840</b>	708	---
Particles >14µm	ASTM D7647 >80	▲ <b>339</b>	▲ 101	---
Particles >21µm	ASTM D7647 >20	▲ <b>114</b>	▲ 37	---
Particles >38µm	ASTM D7647 >4	▲ <b>6</b>	3	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ <b>19/18/16</b>	▲ 17/14	---

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	<b>0.16</b>	0.378	0.366

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### Water (KF)




### Acid Number



### Water (KF)



### Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	▲ MODER
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	47.6	44.5	44.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC127461 **Recieved** : 19 Jan 2024  
**Lab Number** : 06065632 **Diagnosed** : 22 Jan 2024  
**Unique Number** : 10837014 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**CUSTOM MOLDERS**  
 160 MEISTER AVE #1  
 SOMERVILLE, NJ  
 US 08867  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: