


# **OIL ANALYSIS REPORT**

# Machine Id KAESER 5615744 (S/N 1024)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Mar2023	Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA008656	KCPA001312	
Sample Date		Client Info		05 Jan 2024	31 Mar 2023	
Machine Age	hrs	Client Info		43839	37412	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	12	6	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	9	4	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	0	<1	
Zinc	ppm	ASTM D5185m	0	68	68	
Sulfur	ppm	ASTM D5185m	23500	16068	19683	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		2	<1	
Potassium	ppm	ASTM D5185m		0	0	
Water	%	ASTM D6304	>0.05	0.010	0.006	
ppm Water	ppm	ASTM D6304	>500	102	63.2	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		17411	4381	
Particles >6µm		ASTM D7647	>1300	<b>4899</b>	839	
Particles >14μm		ASTM D7647	>80	<u>^</u> 744	52	
Particles >21µm		ASTM D7647	>20	<u>^</u> 259	16	
Particles >38µm		ASTM D7647	>4	11	1	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/17	19/17/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.34	0.39	



## **OIL ANALYSIS REPORT**







Sample No. Lab Number **Unique Number** 

: 06065644

: KCPA008656 : 10837026

Recieved Diagnosed

Diagnostician : Don Baldridge

: 22 Jan 2024

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 24200 MAIN ST CARSON, CA US 90745

Contact: Service Manager

T: F: