




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[SV2309070682]
 Machine Id
YORK HERSHEY 10 - CH 2 (S/N SFHM556880)
 Component
Refrigeration Compressor
 Fluid
YORK TYPE K (10 GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0632044	WC0430749	WC0430690
Sample Date	Client Info	09 Jan 2024	31 May 2023	30 Sep 2022
Machine Age	hrs Client Info	11282	9214	6820
Oil Age	hrs Client Info	11282	0	0
Oil Changed	Client Info	Filtered	Not Changd	Not Changd
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>100	<1	<1	0
Chromium ppm ASTM D5185m	>2	0	0	0
Nickel ppm ASTM D5185m		0	<1	0
Titanium ppm ASTM D5185m		0	0	<1
Silver ppm ASTM D5185m	>2	0	<1	0
Aluminum ppm ASTM D5185m	>50	2	0	<1
Lead ppm ASTM D5185m	>2	0	<1	0
Copper ppm ASTM D5185m	>100	<1	<1	<1
Tin ppm ASTM D5185m	>4	<1	<1	1
Vanadium ppm ASTM D5185m		<1	0	<1
Cadmium ppm ASTM D5185m		0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m	0	0	0	0
Barium ppm ASTM D5185m	0	<1	0	0
Molybdenum ppm ASTM D5185m	0	0	0	<1
Manganese ppm ASTM D5185m	0	0	0	<1
Magnesium ppm ASTM D5185m	0	0	<1	2
Calcium ppm ASTM D5185m	0	0	0	0
Phosphorus ppm ASTM D5185m	5	<1	0	16
Zinc ppm ASTM D5185m	0	0	0	0
Sulfur ppm ASTM D5185m	10	15	13	0

CONTAMINANTS




method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>50	3	0	5
Sodium ppm ASTM D5185m		<1	0	1
Potassium ppm ASTM D5185m	>20	0	<1	0
Water % ASTM D6304	>0.03	0.009	0.009	0.011
ppm Water ppm ASTM D6304	>300	95	93.7	111.2

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974	0.03	0.014	0.026	0.014




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32.0	31.0	32.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0632044 **Received** : 19 Jan 2024
Lab Number : 06065705 **Diagnosed** : 23 Jan 2024
Unique Number : 10837087 **Diagnostician** : Angela Borella
Test Package : IND 2

DAIKIN APPLIED-RICHMOND
 3524 MAYLAND CT
 RICHMOND, VA
 US 23233
 Contact: GANIS HEISLER
 ganis.heisler@daikin.com
 T: (804)747-4822
 F: (804)747-6686

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)