

OIL ANALYSIS REPORT

Area NOT GIVEN [SVO-058662] INGERSOLL RAND VN1063U10317 - CENTURY BRASS Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

		Jan2	024			

Sample Rating Trend




NORMAL

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06065737		
Sample Date		Client Info		13 Jan 2024		
Machine Age	hrs	Client Info		29931		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		593		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		11		
Phosphorus	ppm	ASTM D5185m		11		
Zinc	ppm	ASTM D5185m		1		
Sulfur	ppm	ASTM D5185m		303		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		24		
Potassium	ppm	ASTM D5185m	>20	4		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.172		



OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jan 13/24	Appearance	scalar	*Visual	NORML	NORML			
Jan 1	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water		*Visual		NEG			
	FLUID PROPERT			limit/base	current	biotory1	history	
	Visc @ 40°C		method ASTM D445	IIIIII/Dase	51.2	history1	history2	
				Pare 1 de la colo			h'stam.0	
	SAMPLE IMAGES	5	method	limit/base	current	history1	history2	
Jan 13/24 +	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Metal	5		Jan13/24				
	Viscosity @ 40°C				Acid Number			
	50 Abnormal 5 45 40 Abnormal 40 Abnormal			(0,20) (0,15) (10) (10) (10) (10) (10) (10) (10) (10	24			
Laboratory Sample No.		i01 Madis Recieved Diagnose	: 19 .	ry, NC 27513 Jan 2024 Jan 2024	John JOHN	JOHN HENRY FOSTER COMPAN 4700 LEBOURGET STREE SAINT LOUIS, M US 6310 Contact: RACHEL VON HATTE rvonhatten@jhf.co T: (314)593-126		

Contact/Location: RACHEL VON HATTEN - UCJOHSAI