

OIL ANALYSIS REPORT

S-460 [1403476] KAESER YAC01 - BAE SYSTEMS (S/N 1128) Component

Compressor

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




Sample Rating Trend




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06065741		
Sample Date		Client Info		04 Jan 2024		
Machine Age	hrs	Client Info		4851		
Oil Age	hrs	Client Info		4851		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	6		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	17		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	12		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		10		
Sulfur	ppm	ASTM D5185m		16588		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		9		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33		



OIL ANALYSIS REPORT





VISUAL		methou			Thistory I	Thistory Z	
White Metal	scalar	*Visual	NONE	NONE			
Yellow Metal	scalar	*Visual	NONE	NONE			
Precipitate		*Visual	NONE	NONE			
Silt		*Visual	NONE	NONE			
Debris		*Visual	NONE	LIGHT			
Sand/Dirt		*Visual	NONE	NONE			
Appearance		*Visual	NORML	NORML			
Odor		*Visual	NORML	NORML			
Emulsified Water		*Visual	>0.05	NEG			
Free Water		*Visual	>0.05	NEG			
				NEG			
FLUID PROPERT	IES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	46	44.3			
SAMPLE IMAGES	6	method	limit/base	current	history1	history2	
Color				a.	no image	no image	
Bottom					no image	no image	
ton ton hormium nickel			Jan4/24				
Non-ferrous Metals	5		67				
Viscosity @ 40°C			0.50	Acid Number			
Abnormal Abnormal Abnormal 4 72/b ter			(0,0.50 (0,0.40) (0,0.40) (0,0.00) (0,0] =] =] =		2	
WearCheck USA - 501 Madison Ave., Cary, NC 27513UCH06065741Recieved: 19 Jan 202406065741Diagnosed: 22 Jan 202410837123Diagnostician: Don BaldridgeIND 2Intact Customer Service at 1-800-237-1369.outside of the ISO 17025 scope of accreditation.					AIR TECHNOLOGIES INC (INE 8405 E 30TH S INDIANAPOLIS, II US 4621 Contact: GLEN PARKEI glen.parker@aircompressors.cor T: (765)516-492		

To discuss this sample report, * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Sample No. Lab Number **Unique Number Test Package**

F: