




FUEL REPORT

Sample Rating Trend



ISO



Machine Id
NYU 240 E 38ST MAIN

Component
Diesel Fuel
Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (2000 GAL)

DIAGNOSIS

▲ Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

▲ Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|----------|
| Sample Number | Client Info | | | WC06073446 | WC05761169 | --- |
| Sample Date | Client Info | | | 29 Jan 2024 | 07 Feb 2023 | --- |
| Machine Age | hrs | Client Info | | 0 | 0 | --- |
| Sample Status | | | | ATTENTION | ATTENTION | --- |

| PHYSICAL PROPERTIES | | method | limit/base | current | history1 | history2 |
|---------------------|--------|----------------|------------|--------------|----------|----------|
| Specific Gravity | | *ASTM D1298 | 0.839 | 0.842 | 0.841 | --- |
| Fuel Color | text | *Visual Screen | Yellow | Red | Red | --- |
| ASTM Color | scalar | *ASTM D1500 | | L4.0 | L4.0 | --- |
| Visc @ 40°C | cSt | ASTM D445 | 3.0 | 2.48 | 2.57 | --- |

| SULFUR CONTENT | | method | limit/base | current | history1 | history2 |
|----------------|-----|-------------|------------|----------|----------|----------|
| Sulfur | ppm | ASTM D5185m | 10 | 0 | 0 | --- |
| Sulfur (UVF) | ppm | ASTM D5453 | | 7 | 7 | --- |






| DISTILLATION | | method | limit/base | current | history1 | history2 |
|------------------------|----|----------|------------|------------|----------|----------|
| Initial Boiling Point | °C | ASTM D86 | 165 | 167 | 164 | --- |
| 5% Distillation Point | °C | ASTM D86 | | 191 | 191 | --- |
| 10% Distill Point | °C | ASTM D86 | 201 | 200 | 201 | --- |
| 15% Distillation Point | °C | ASTM D86 | | 209 | 212 | --- |
| 20% Distill Point | °C | ASTM D86 | 216 | 218 | 220 | --- |
| 30% Distill Point | °C | ASTM D86 | 230 | 233 | 237 | --- |
| 40% Distill Point | °C | ASTM D86 | 243 | 249 | 252 | --- |
| 50% Distill Point | °C | ASTM D86 | 255 | 264 | 267 | --- |
| 60% Distill Point | °C | ASTM D86 | 267 | 280 | 283 | --- |
| 70% Distill Point | °C | ASTM D86 | 280 | 296 | 298 | --- |
| 80% Distill Point | °C | ASTM D86 | 295 | 313 | 314 | --- |
| 85% Distillation Point | °C | ASTM D86 | | 321 | 322 | --- |
| 90% Distill Point | °C | ASTM D86 | 310 | 330 | 330 | --- |
| 95% Distillation Point | °C | ASTM D86 | | 344 | 342 | --- |
| Final Boiling Point | °C | ASTM D86 | 341 | 352 | 350 | --- |
| Distillation Residue | % | ASTM D86 | 3.0 | 1.4 | 1.4 | --- |
| Distillation Loss | % | ASTM D86 | 3.0 | 0.7 | 0.7 | --- |

| IGNITION QUALITY | | method | limit/base | current | history1 | history2 |
|------------------|--|------------|------------|-------------|----------|----------|
| API Gravity | | ASTM D7777 | 37.7 | 36.6 | 36.8 | --- |
| Cetane Index | | ASTM D4737 | <40.0 | 48.5 | 49.3 | --- |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | <1.0 | 0 | 0 | --- |
| Sodium | ppm | ASTM D5185m | <0.1 | 0 | 0 | --- |
| Potassium | ppm | ASTM D5185m | <0.1 | 0 | <1 | --- |
| Water | % | ASTM D6304 | <0.05 | 0.006 | 0.004 | --- |
| ppm Water | ppm | ASTM D6304 | <500 | 66 | 42.9 | --- |
| % Gasoline | % | *In-House | <0.50 | 0.0 | 0.0 | --- |
| % Biodiesel | % | *In-House | <20.0 | 6.7 | 7.0 | --- |




FUEL REPORT





| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|------------|------------|----------|
| Particles >4µm | ASTM D7647 | >2500 | ▲ 10831 | ▲ 5468 | --- |
| Particles >6µm | ASTM D7647 | >640 | ▲ 3262 | ▲ 1468 | --- |
| Particles >14µm | ASTM D7647 | >80 | ▲ 304 | 43 | --- |
| Particles >21µm | ASTM D7647 | >20 | ▲ 86 | 7 | --- |
| Particles >38µm | ASTM D7647 | >4 | 3 | 1 | --- |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | --- |
| Oil Cleanliness | ISO 4406 (c) | >18/16/13 | ▲ 21/19/15 | ▲ 20/18/13 | --- |

| HEAVY METALS | method | limit/base | current | history1 | history2 |
|--------------|--------|-------------|---------|----------|----------|
| Aluminum | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | <0.1 | 0 | <1 |
| Lead | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Iron | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | <0.1 | 0 | 0 |
| Zinc | ppm | ASTM D5185m | <0.1 | 0 | 0 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
| Color | | | | | |
| Bottom | | | | | |



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC06073446 **Received** : 29 Jan 2024
Lab Number : 06073446 **Diagnosed** : 06 Feb 2024
Unique Number : 10850123 **Diagnostician** : Doug Bogart
Test Package : DF-1 (Additional Tests: Screen)

ISP FUEL SYSTEMS
 9 CHRIS COURT, SUITE F
 DAYTON, NJ
 US 08810
 Contact: AJ THOMPSON
 aj@ispfuelsystems.com
 T:
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)