




FUEL REPORT

Sample Rating Trend

NORMAL



Machine Id
NYU KIMMEL FARM TANK 2

Component
Diesel Fuel
Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (25000 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC06073452	WC05761168	WC05461855
Sample Date	Client Info	29 Jan 2024	07 Feb 2023	07 Feb 2022
Machine Age	hrs	Client Info	0	0
Sample Status			NORMAL	NORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.839	0.840	0.841
Fuel Color	text	*Visual Screen	Yellow	Red
ASTM Color	scalar	*ASTM D1500	L4.0	L4.0
Visc @ 40°C	cSt	ASTM D445	3.0	2.5

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0
Sulfur (UVF)	ppm	ASTM D5453		6

DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	160
5% Distillation Point	°C	ASTM D86		187
10% Distill Point	°C	ASTM D86	201	199
15% Distillation Point	°C	ASTM D86		209
20% Distill Point	°C	ASTM D86	216	218
30% Distill Point	°C	ASTM D86	230	234
40% Distill Point	°C	ASTM D86	243	250
50% Distill Point	°C	ASTM D86	255	265
60% Distill Point	°C	ASTM D86	267	280
70% Distill Point	°C	ASTM D86	280	295
80% Distill Point	°C	ASTM D86	295	311
85% Distillation Point	°C	ASTM D86		320
90% Distill Point	°C	ASTM D86	310	330
95% Distillation Point	°C	ASTM D86		344
Final Boiling Point	°C	ASTM D86	341	352
Distillation Residue	%	ASTM D86	3.0	1.4
Distillation Loss	%	ASTM D86	3.0	0.9

IGNITION QUALITY

method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	37.0	36.8
Cetane Index	ASTM D4737	<40.0	49.2	49.1


CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0
Sodium	ppm	ASTM D5185m	<0.1	0
Potassium	ppm	ASTM D5185m	<0.1	0
Water	%	ASTM D6304	<0.05	0.006
ppm Water	ppm	ASTM D6304	<500	68
% Gasoline	%	*In-House	<0.50	0.0
% Biodiesel	%	*In-House	<20.0	3.7




FUEL REPORT

Fuel Distillation Curve




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	947	4619	1529
Particles >6µm	ASTM D7647	>640	281	1112	346
Particles >14µm	ASTM D7647	>80	34	20	25
Particles >21µm	ASTM D7647	>20	9	3	6
Particles >38µm	ASTM D7647	>4	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	17/15/12	19/17/11	18/16/12

Particle Count



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	0
Nickel	ppm	ASTM D5185m <0.1	0	<1	0
Lead	ppm	ASTM D5185m <0.1	0	0	0
Vanadium	ppm	ASTM D5185m <0.1	0	0	0
Iron	ppm	ASTM D5185m <0.1	0	0	0
Calcium	ppm	ASTM D5185m <0.1	0	0	0
Magnesium	ppm	ASTM D5185m <0.1	0	0	0
Phosphorus	ppm	ASTM D5185m <0.1	0	0	2
Zinc	ppm	ASTM D5185m <0.1	0	0	0

Water (KF)




SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom



Viscosity @ 40°C



Particle Trend



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC06073452
 Lab Number : **06073452**
 Unique Number : 10850129
 Test Package : DF-1 (Additional Tests: Screen)

Received : 30 Jan 2024
 Diagnosed : 06 Feb 2024
 Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ISP FUEL SYSTEMS
 9 CHRIS COURT, SUITE F
 DAYTON, NJ
 US 08810
 Contact: AJ THOMPSON
 aj@ispfuelsystems.com

T:
F: