

FUEL REPORT

NYU 240 E 38 ST GENERATOR BASE

Diesel Fuel

{not provided} (250 GAL)

DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion


All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06073459	WC05761163	
Sample Date		Client Info		29 Jan 2024	07 Feb 2023	
Machine Age	hrs	Client Info		0	0	
Sample Status				ATTENTION	NORMAL	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.842	0.841	
Fuel Color	text	*Visual Screen		Red	Red	
ASTM Color	scalar	*ASTM D1500		L4.0	L4.0	
Visc @ 40°C	cSt	ASTM D445		2.46	2.56	
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0	0	
Sulfur (UVF)	ppm	ASTM D5453		7	8	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		168	164	
5% Distillation Point	°C	ASTM D86		191	189	
10% Distill Point	°C	ASTM D86		201	201	
15% Distillation Point	°C	ASTM D86		210	211	
20% Distill Point	°C	ASTM D86		218	220	
30% Distill Point	°C	ASTM D86		234	236	
40% Distill Point	°C	ASTM D86		249	251	
50% Distill Point	°C	ASTM D86		265	267	
60% Distill Point	°C	ASTM D86		281	283	
70% Distill Point	°C	ASTM D86		297	298	
80% Distill Point	°C	ASTM D86		313	314	
85% Distillation Point	°C	ASTM D86		321	322	
90% Distill Point	°C	ASTM D86		331	330	
95% Distillation Point	°C	ASTM D86		344	342	
Final Boiling Point	°C	ASTM D86		352	350	
Distillation Residue	%	ASTM D86		1.4	1.4	
Distillation Loss	%	ASTM D86		0.8	0.7	
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.6	36.8	
Cetane Index		ASTM D4737	<40.0	48.7	49.1	

API Gravity		ASTM D7777		36.6	36.8	
Cetane Index		ASTM D4737	<40.0	48.7	49.1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	
Sodium	ppm	ASTM D5185m	<0.1	0	0	
Potassium	ppm	ASTM D5185m	<0.1	0	<1	
Water	%	ASTM D6304	<0.05	0.006	0.004	
ppm Water	ppm	ASTM D6304	<500	66	47.3	
% Gasoline	%	*In-House	<0.50	0.0	0.0	
% Biodiesel	%	*In-House	<20.0	6.5	6.9	



0. Feb7/23

6

cSt (40°C)

Π. Feb7/23

400°

350°0

<u>ି</u> 300°C 250°C E 200° 150°0 100

> Ē

Abnorma

Abnormal

Viscosity @ 40°C

Fuel Distillation Curve

Sample

-Baseline

% 20% 30% 40% 50% Percent Reco

FUEL REPORT



	T ²⁶	FLUID CLEANLIN	VESS	method	limit/base	current	history1	history2
	-24	Particles >4µm		ASTM D7647	>2500	5107	4879	
	-22 8	Particles >6µm		ASTM D7647	>640	1697	1180	
	4406:1999 Cleanliness	Particles >14µm		ASTM D7647	>80	2 14	25	
	-16 Cle	Particles >21µm		ASTM D7647	>20	6 5	2	
	-14 anline	Particles >38µm		ASTM D7647	>4	2	0	
	12 %	Particles >71µm		ASTM D7647	>3	0	0	
	-8	Oil Cleanliness		ISO 4406 (c)	>18/16/13	20/18/15	19/17/12	
21µ 38µ 7	16 11μ	HEAVY METALS		method	limit/base	current	history1	history2
		Aluminum	ppm	ASTM D5185m	<0.1	0	0	
		Nickel	ppm	ASTM D5185m	<0.1	0	<1	
		Lead	ppm	ASTM D5185m	<0.1	0	0	
		Vanadium	ppm	ASTM D5185m	<0.1	0	0	
		Iron	ppm	ASTM D5185m	<0.1	0	0	
		Calcium	ppm	ASTM D5185m	<0.1	0	0	
		Magnesium	ppm	ASTM D5185m		0	0	
***************************************		Phosphorus	ppm	ASTM D5185m		0	<1	
	23	Zinc	ppm	ASTM D5185m		0	0	
		SAMPLE IMAGE		method	limit/base	current	history1	history2
		Color						no image
	Jan29/24	Bottom						no image
	Jai	GRAPHS						
	1000	Fuel Distillation Cu	urve			Pensky-Marten	s Flash Point (°	°C)
	30°(50°(\$0°(20°(C - Sample Baseline			temperature °C	Ee)/23		
	00°(/			Feb		
	Jan 29,		/					
2	년 전 220°0							
	200°(
	-	1						
-tt-	180°(4						
	160°(C -						
	140°(c -						
	120°(_		<u> </u>			
*0 *0 *0 *0 *0 *0 *0 *0 *0 *0 *0 *0 *0 *	2	0% 10% 30% 30%	S S S S S S S S S S S S S S S S S S S	70%	90% 100%			
Laborator	o. :		501 Madis Recieved Diagnose Diagnosti	:30 . ed::06 F	ry, NC 2751 Jan 2024 Feb 2024 Ig Bogart	3	ISP FU 9 CHRIS CO	EL SYSTEN URT, SUITE DAYTON, N

Contact/Location: AJ THOMPSON - ISPDAY