




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
BLACKJACK CREEK [700007683]
 Machine Id
21WEA88408 - E-01 (S/N 11628063)
 Component
Wind Turbine Gearbox
 Fluid
FUCHS RENOLIN UNISYN CKC ISO 320 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	NX015714	NX011517	---
Sample Date	Client Info	18 Dec 2023	04 Jan 2023	---
Machine Age	hrs	0	2600	---
Oil Age	hrs	661288	0	---
Oil Changed	Client Info	N/A	N/A	---
Sample Status		ABNORMAL	ABNORMAL	---

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184 >40	18	23	---
Iron	ppm ASTM D5185m >55	40	34	---
Chromium	ppm ASTM D5185m >2	0	0	---
Nickel	ppm ASTM D5185m >2	0	0	---
Titanium	ppm ASTM D5185m >10	0	0	---
Silver	ppm ASTM D5185m	0	0	---
Aluminum	ppm ASTM D5185m >15	0	0	---
Lead	ppm ASTM D5185m >3	2	<1	---
Copper	ppm ASTM D5185m >7	<1	<1	---
Tin	ppm ASTM D5185m >3	0	<1	---
Vanadium	ppm ASTM D5185m	0	0	---
Cadmium	ppm ASTM D5185m	0	0	---

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 25	3	5	---
Barium	ppm ASTM D5185m	0	0	---
Molybdenum	ppm ASTM D5185m	0	0	---
Manganese	ppm ASTM D5185m	<1	<1	---
Magnesium	ppm ASTM D5185m	0	<1	---
Calcium	ppm ASTM D5185m 17	10	21	---
Phosphorus	ppm ASTM D5185m 200	179	217	---
Zinc	ppm ASTM D5185m	0	5	---
Sulfur	ppm ASTM D5185m 5000	4783	4485	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >35	16	12	---
Sodium	ppm ASTM D5185m	2	0	---
Potassium	ppm ASTM D5185m >20	0	2	---
Water	% ASTM D6304 >0.02	0.006	0.005	---
ppm Water	ppm ASTM D6304 >200	62	53.5	---

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	76788	293920	---
Particles >6µm	ASTM D7647 >320	▲ 3745	▲ 152296	---
Particles >14µm	ASTM D7647 >40	29	▲ 3795	---
Particles >21µm	ASTM D7647 >10	4	▲ 407	---
Particles >38µm	ASTM D7647 >3	0	▲ 9	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >--/15/12	▲ 23/19/12	▲ 25/24/19	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.9	0.36	0.44	---




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	LIGHT	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.02	NEG	NEG	---
Free Water	scalar	*Visual		NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	315	318	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX015714 **Received** : 30 Jan 2024
Lab Number : 06073850 **Diagnosed** : 31 Jan 2024
Unique Number : 10855941 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

NORDEX USA - Chicago
 300 SOUTH WACKER DRIVE, SUITE 1500
 CHICAGO, IL
 US 60606
 Contact: DEVIN LINEHAN
 DLinehan@nordex-online.com
 T: (312)386-4124
 F: (312)386-7102

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)