


# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**KAESER AS 20 6015903 (S/N 1238)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) FG-460 (--- QTS)**

**DIAGNOSIS**

**▲ Recommendation**

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**▲ Wear**

The aluminum level is abnormal. All other component wear rates are normal.

**▲ Contamination**

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCP40070D</b>	KCP48296	---
Sample Date	Client Info			<b>13 Sep 2023</b>	21 Aug 2022	---
Machine Age	hrs	Client Info		<b>18563</b>	17254	---
Oil Age	hrs	Client Info		<b>0</b>	4000	---
Oil Changed	Client Info			<b>Changed</b>	Changed	---
Sample Status				<b>ABNORMAL</b>	ABNORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>8</b>	2	---
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>10	<b>▲ 14</b>	4	---
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	---
Copper	ppm	ASTM D5185m	>50	<b>5</b>	2	---
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	---
Barium	ppm	ASTM D5185m		<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Magnesium	ppm	ASTM D5185m		<b>0</b>	0	---
Calcium	ppm	ASTM D5185m		<b>0</b>	0	---
Phosphorus	ppm	ASTM D5185m	500	<b>165</b>	117	---
Zinc	ppm	ASTM D5185m		<b>223</b>	50	---
Sulfur	ppm	ASTM D5185m		<b>1388</b>	1519	---


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>0</b>	0	---
Sodium	ppm	ASTM D5185m		<b>12</b>	<1	---
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	---
Water	%	ASTM D6304	>0.05	<b>0.012</b>	0.003	---
ppm Water	ppm	ASTM D6304	>500	<b>130</b>	38.9	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>54053</b>	27508	---
Particles >6µm		ASTM D7647	>1300	<b>▲ 3636</b>	▲ 11949	---
Particles >14µm		ASTM D7647	>80	<b>36</b>	▲ 1300	---
Particles >21µm		ASTM D7647	>20	<b>9</b>	▲ 222	---
Particles >38µm		ASTM D7647	>4	<b>0</b>	▲ 10	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>▲ 23/19/12</b>	▲ 22/21/17	---


FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	<b>0.48</b>	0.40	---

# OIL ANALYSIS REPORT


## ▲ Particle Trend




## ▲ Aluminum (ppm)




## Water (KF)



## Acid Number




## Water (KF)








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	48.2	46.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCP40070D **Received** : 30 Jan 2024  
**Lab Number** : 06073884 **Diagnosed** : 31 Jan 2024  
**Unique Number** : 10855975 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**RIVER OAKS ORCHARDS**  
 9839 HUTCHINSON RD  
 MANTECA, CA  
 US 95337  
 Contact: BRAD  
 BRAD@RIVEROAKORCHARDS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: