

# **PROBLEM SUMMARY**

Sample Rating Trend

WATER


Dec15/23

#### Machine Ic KAESER 7836092 (S/N 1062) Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

We recommend you service the filters on this component. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS							
Sample Status				SEVERE			
Water	%	ASTM D6304	>0.05	<b>0.080</b>			
ppm Water	ppm	ASTM D6304	>500	<u> </u>			
Particles >6µm		ASTM D7647	>1300	<u> </u>			
Particles >14µm		ASTM D7647	>80	🔺 854			
Particles >21µm		ASTM D7647	>20	<u> </u>			
Particles >38µm		ASTM D7647	>4	<b>4</b> 4			
Particles >71µm		ASTM D7647	>3	<u> </u>			
Oil Cleanliness		ISO 4406 (c)	>17/13	<b> 20/17</b>			
Free Water	scalar	*Visual		<b> </b> >10%			

Customer Id: AMCBAT Sample No.: KC111630 Lab Number: 06073885 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED AC	IMENDED ACTIONS					
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS



WATER

## Machine Id KAESER 7836092 (S/N 1062)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil. Excessive free water present. There is a light concentration of water present in the oil.


### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM		method	limit/base	current	history1	history2
			IIIIII/Dase			TIIStoryz
Sample Number		Client Info		KC111630		
Sample Date		Client Info		15 Dec 2023		
Machine Age	hrs	Client Info		17091		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				SEVERE		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	14		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	0		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
CONTAMINANTS		ام و داخ و در				
		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	limit/base	current <1	history1	history2
Silicon Sodium	ppm ppm					
		ASTM D5185m		<1		
Sodium	ppm	ASTM D5185m ASTM D5185m	>25	<1 0		
Sodium Potassium	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	>25 >20	<1 0 0		
Sodium Potassium Water	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304	>25 >20 >0.05	<1 0 0 • 0.080		
Sodium Potassium Water ppm Water	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304	>25 >20 >0.05 >500	<1 0 0 • 0.080 • 800		
Sodium Potassium Water ppm Water FLUID CLEANLIN	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 method	>25 >20 >0.05 >500 limit/base	<1 0 0 ▲ 0.080 ▲ 800 current	   history1	
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 <b>method</b> ASTM D7647	>25 >20 >0.05 >500 limit/base	<1 0 0 0 0.080 3 800 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	   history1	   history2
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 <b>method</b> ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 Iimit/base >1300 >80	<1 0 0 0 0.080 800 <u>current</u> 9213 5019	   history1 	   history2 
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 <b>Method</b> ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 Iimit/base >1300 >80	<1 0 0 ▲ 0.080 ▲ 800 Current 9213 ▲ 5019 ▲ 854	   history1  	  history2 
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 ASTM D6304 <b>Method</b> ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 <b>limit/base</b> >1300 >80 >20	<1 0 0 0.080 800 Current 9213 5019 854 288	  history1  	 history2
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	ppm ppm % ppm	ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 ASTM D6304 <b>Method</b> ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 <b>limit/base</b> >1300 >80 >20 >4	<1 0 0 0.080 ▲ 800 Current 9213 ▲ 5019 ▲ 854 ▲ 288 ▲ 44	  history1  	  history2
Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >21µm Particles >38µm Particles >71µm	ppm ppm % ppm ESS	ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 ASTM D6304 METHOD ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 <b>limit/base</b> >1300 >80 >20 >4 >3	<1 0 0 0.080 ▲ 0.080 ▲ 800 Current 9213 ▲ 5019 ▲ 854 ▲ 288 ▲ 44 ▲ 5	  history1    	  history2    



# **OIL ANALYSIS REPORT**





: 30 Jan 2024

: 02 Feb 2024 : Jonathan Hester





AMCOR 475 NORTH KIRK RD BATAVIA, IL US 60510 Contact: Service Manager

Certificate 12367 Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Deci

4406

:1999 Cle

14

47

40

38

Abnorma

Contact/Location: Service Manager - AMCBAT

history1