

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER CSD 75T 8558528 (S/N 1267)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2023	Jan2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011052	KCPA005487	
Sample Date		Client Info		17 Jan 2024	25 May 2023	
Machine Age	hrs	Client Info		4773	2076	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	<1	3	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	5	6	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	nnm	ASTM D5185m	0	0	0	
	ppm	ASTM D5185m	90	0	0	
Barium Molybdenum	ppm	ASTM D5185m	0	0	<1	
	ppm		U	0		
Manganese	ppm	ASTM D5185m ASTM D5185m	100	2	<1 15	
Magnesium Calcium	ppm	ASTM D5185m	0	0	0	
	ppm	ASTM D5185m	0	0	0	
Phosphorus Zinc	ppm		0	11	21	
Sulfur	ppm	ASTM D5185m ASTM D5185m	23500	19339	21310	
	ppm					
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		4	3	
Potassium	ppm	ASTM D5185m		<1	2	
Water	%	ASTM D6304		0.006	0.009	
ppm Water	ppm	ASTM D6304	>500	70	92.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647			2977	
Particles >6µm		ASTM D7647			667	
Particles >14μm		ASTM D7647	>80		40	
Particles >21μm		ASTM D7647	>20		10	
Particles >38μm		ASTM D7647	>4		1	
Particles >71μm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		19/17/12	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.42	0.44	



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: 06073996

: KCPA011052 : 10856087

Recieved : 30 Jan 2024 Diagnosed : 31 Jan 2024

Diagnostician : Doug Bogart Test Package : IND 2 (Additional Tests: KF, PrtCount)

CELGARD 13610 S RIDGE DR CHARLOTTE, NC

US Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: