



FUEL REPORT


Sample Rating Trend

VIS DEBRIS

Machine Id
Electricities - TANK 6 - Greenville

Component
Diesel Fuel
Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. All other laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Fuel content negligible. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0869470	WCDF03697	---
Sample Date	Client Info		25 Jan 2024	13 Apr 2021	---
Machine Age	hrs	Client Info	0	0	---
Sample Status			ABNORMAL	ABNORMAL	---

PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.839	0.840	0.839	---
Fuel Color	text	*Visual Screen	Red	Red	---
ASTM Color	scalar	*ASTM D1500	L4.5	L6.0	---
Visc @ 40°C	cSt	ASTM D445	3.0	2.42	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	58	62	---

SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0	---
Sulfur (UVF)	ppm	ASTM D5453	7	6	---

DISTILLATION

	method	limit/base	current	history1	history2	
Initial Boiling Point	°C	ASTM D86	165	161	164	---
5% Distillation Point	°C	ASTM D86		187	192	---
10% Distill Point	°C	ASTM D86	201	197	201	---
15% Distillation Point	°C	ASTM D86		206	209	---
20% Distill Point	°C	ASTM D86	216	214	217	---
30% Distill Point	°C	ASTM D86	230	229	231	---
40% Distill Point	°C	ASTM D86	243	243	245	---
50% Distill Point	°C	ASTM D86	255	257	259	---
60% Distill Point	°C	ASTM D86	267	272	274	---
70% Distill Point	°C	ASTM D86	280	288	289	---
80% Distill Point	°C	ASTM D86	295	304	307	---
85% Distillation Point	°C	ASTM D86		314	317	---
90% Distill Point	°C	ASTM D86	310	326	327	---
95% Distillation Point	°C	ASTM D86		343	340	---
Final Boiling Point	°C	ASTM D86	341	352	349	---
Distillation Residue	%	ASTM D86	3.0	1.4	1.4	---
Distillation Loss	%	ASTM D86	3.0	0.7	0.8	---

IGNITION QUALITY




	method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	37.0	37.2	---
Cetane Index	ASTM D4737	<40.0	47.9	48.7	---

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	<1.0	0	0	---
Sodium	ppm	ASTM D5185m	<0.1	<1	<1	---
Potassium	ppm	ASTM D5185m	<0.1	0	0	---
Water	%	ASTM D6304	<0.05	0.005	0.009	---
ppm Water	ppm	ASTM D6304	<500	54	95.3	---
% Gasoline	%	*In-House	<0.50	0.0	0.0	---
% Biodiesel	%	*In-House	<20.0	0.0	5.2	---



FUEL REPORT






MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	0	▲ 100	---
Yeast	CFU/ml WC-Method	>=100000	0	▲ 1000	---
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	0	---
Nickel	ppm ASTM D5185m	<0.1	<1	0	---
Lead	ppm ASTM D5185m	<0.1	0	1	---
Vanadium	ppm ASTM D5185m	<0.1	0	0	---
Iron	ppm ASTM D5185m	<0.1	0	0	---
Calcium	ppm ASTM D5185m	<0.1	<1	0	---
Magnesium	ppm ASTM D5185m	<0.1	<1	0	---
Phosphorus	ppm ASTM D5185m	<0.1	0	0	---
Zinc	ppm ASTM D5185m	<0.1	0	0	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0869470 **Received** : 30 Jan 2024
Lab Number : 06074273 **Diagnosed** : 06 Feb 2024
Unique Number : 10856364 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: BACTERIA, Screen)

VITAL FUEL SYSTEMS
 1076 CLASSIC RD
 APEX, NC
 US 27539
 Contact: JOHN MORREALE
 jmorreale@vitalfuelsystems.com
 T: (919)629-8180
 F: (919)303-7399

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)