


# **OIL ANALYSIS REPORT**

# IBACO [CONHER] **BM ISMAR 8 MAIN ENGINE**

Component

**Transmission (Manual)** 

**RALOY SAE 50 (60 LTR)** 



Sample Rating Trend



### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the fluid.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

		Mar2022	Oct2022 Oct2022	2 Apr2023 Sep2023	Jan2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KL0013482	KL0012809	KL0011417
Sample Date		Client Info		18 Jan 2024	16 Sep 2023	06 Apr 2023
Machine Age	hrs	Client Info		13767	12438	12436
Oil Age	hrs	Client Info		1329	494	492
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ATTENTION	ATTENTION	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	5	9	9
Chromium	ppm	ASTM D5185m	>5	<1	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>7	0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	<1	<1
Lead	ppm	ASTM D5185m	>45	6	8	4
Copper	ppm	ASTM D5185m	>225	22	28	21
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		2	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		11	10	10
Calcium	ppm	ASTM D5185m		3333	3437	3426
Phosphorus	ppm	ASTM D5185m		886	906	904
Zinc	ppm	ASTM D5185m		824	815	815
Sulfur	ppm	ASTM D5185m		6740	6329	6228
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>125	6	9	12
Sodium	ppm	ASTM D5185m		0	1	<1
Potassium	ppm	ASTM D5185m	>20	3	<1	0
FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		28083	80556	90761
Particles >6µm		ASTM D7647	>2500	<b>3133</b>	<b>4707</b>	<u>▲</u> 6961
Particles >14μm		ASTM D7647	>320	74	98	43
Particles >21μm		ASTM D7647	>80	16	24	7
Particles >38μm		ASTM D7647	>20	1	2	1
Particles >71µm		ASTM D7647	>4	0	1	1
Oil Cleanliness		ISO 4406 (c)	>18/15	<b>19/13</b>	<b>1</b> 9/14	<u>^</u> 20/13
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
A	1/01::	4 OT1 4 D oc :-		0.74		

Acid Number (AN)


mg KOH/g ASTM D8045

0.71

0.87



## OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: KL0013482 : 06074663 : 10856754

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Recieved Diagnosed

Diagnostician Test Package : MOB 2 ( Additional Tests: PrtCount )

: 30 Jan 2024 : 01 Feb 2024 : Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MX 83140 Contact: EDUARDO GARCIA egarcia.comsa@gmail.com

T: (526)622-1581 x:81

F: x: