

OIL ANALYSIS REPORT

Sam

Sample Rating Trend

NORMAL



REXROTH HPU 6

Component

Hydraulic System

SHELL TELLUS S3 M 46 (106 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		L		Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO60001878		
Sample Date		Client Info		16 Dec 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>40	9		
Chromium	ppm	ASTM D5185m	>4	<1		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>4	2		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>60	4		
Tin	ppm	ASTM D5185m	>4	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	3	0		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	0	1		
Calcium	ppm	ASTM D5185m	0	23		
Phosphorus	ppm	ASTM D5185m	106	231		
Zinc	ppm	ASTM D5185m	0	275		
Sulfur	ppm	ASTM D5185m		2577		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	2		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.005		
ppm Water	ppm	ASTM D6304	>500	52		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	391		
Particles >6µm		ASTM D7647	>1300	163		
Particles >14μm		ASTM D7647	>160	26		
Particles >21µm		ASTM D7647	>40	7		
Particles >38μm		ASTM D7647	>10	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/15/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A si al Niversala au (ANI)	ma 1/011/-	ACTM DOGGE		0.20		


Acid Number (AN)

mg KOH/g ASTM D8045

0.32



OIL ANALYSIS REPORT





Certificate L2367

Lab Number

Unique Number

: 06074679

Diagnosed : 10856770

Diagnostician Test Package : IND 2 (Additional Tests: KF, KV100, VI)

: 01 Feb 2024

: Jonathan Hester

US 89115 Contact: TONY DAVIS TONY.DAVIS@MOTION.COM T:

Contact/Location: TONY DAVIS - MOTLAS

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (702)651-9466