


Machine Id
GARDNER DENVER S202859 - LONGHORN LOCKERS
 Component
Compressor
 Fluid
QUINCY QUINSYN (--- GAL)



DIAGNOSIS

- Recommendation**
 We advise that you check for a possible overheat condition. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.
- Wear**
 All component wear rates are normal.
- Contamination**
 There is a moderate amount of particulates present in the oil.
- Fluid Condition**
 The oil viscosity is higher than normal. The AN level is at the top-end of the recommended limit. Confirm oil type.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			TO50001872	QUC0000535	QUC0000458
Sample Date	Client Info			08 Jan 2024	20 Oct 2023	28 Jul 2023
Machine Age	hrs	Client Info		67023	66507	65834
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			Changed	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	19	15	15
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m		<1	<1	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	▲ 29	22	23
Lead	ppm	ASTM D5185m	>25	<1	0	0
Copper	ppm	ASTM D5185m	>50	29	13	7
Tin	ppm	ASTM D5185m	>15	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		1	3	2
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	<1	2
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		104	126	124
Zinc	ppm	ASTM D5185m		780	372	198
Sulfur	ppm	ASTM D5185m		317	457	372

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		0	<1	3
Potassium	ppm	ASTM D5185m	>20	2	<1	<1
Water	%	ASTM D6304	>0.1	0.041	0.018	0.072
ppm Water	ppm	ASTM D6304	>1000	413	184.1	727.2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ 18058	▲ 17036	▲ 10767
Particles >6µm		ASTM D7647	>2500	▲ 3325	▲ 3456	▲ 2559
Particles >14µm		ASTM D7647	>320	152	187	200
Particles >21µm		ASTM D7647	>80	28	45	49
Particles >38µm		ASTM D7647	>20	1	4	3
Particles >71µm		ASTM D7647	>4	0	1	1
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ 21/19/14	▲ 21/19/15	▲ 21/19/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	.10	▲ 2.00	▲ 1.67	▲ 2.99


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.6	▲ 62.4	▲ 56.8
Visc @ 100°C	cSt	ASTM D445	7.8	▲ 9.5	▲ 9.2
Viscosity Index (VI)	Scale	ASTM D2270	132	133	142

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001872 **Received** : 30 Jan 2024
Lab Number : 06074713 **Diagnosed** : 01 Feb 2024
Unique Number : 10856804 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

QUALITY COMPRESSOR
 4428 CR 616
 ALVARADO, TX
 US 76009
 Contact: SEAN
 SEAN@QCOMPRESSOR.COM
 T: (817)822-1333
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)