

PROBLEM SUMMARY

Sample Rating Trend


ISO




TM 11 WEST SIDE AIR FAN PUMP


Pump Fluid


ROYAL PURPLE SYNFILM 150 (--- GAL)







COMPONENT CONDITION SUMMARY









RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ABNORMAL	SEVERE			
Silicon	ppm	ASTM D5185m	>60	△ 69	1	3			
Particles >4µm		ASTM D7647	>5000	60734		576			
Particles >6µm		ASTM D7647	>1300	12419		314			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	23/21/14		16/15/13			

Customer Id: KIMMOBTM11 Sample No.: RP0038092 Lab Number: 06074730 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

08 Jun 2017 Diag: Doug Bogart

VIS DEBRIS



Aside from particulates, the condition of the oil is suitable for further service. However, we recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. High concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



21 Apr 2011 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. Free water present. There is a trace of moisture present in the oil. The amount and size of particulates present in the system is acceptable. The condition of oil is suitable for further service.

View report

18 Mar 2011 Diag: Jonathan Hester

VIS DEBRIS



We were unable to perform a particle count due to a high concentration of particles present in this sample. Aside from particulates, the condition of the oil is suitable for further service. However, we recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. High concentration of visible dirt/debris present in the oil. There is a trace of moisture present in the oil. The condition of oil is suitable for further service.





OIL ANALYSIS REPORT

SAMPLE INFORMATION

ISO



TM 11 Machine Id TM 11 WEST SIDE AIR FAN PUMP

Pump

ROYAL PURPLE SYNFILM 150 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

▲ Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid

1		
	-	

Sample Number		Client Info		RP0038092	RP183402	RP69318
Sample Date		Client Info		29 Jan 2024	08 Jun 2017	21 Apr 2011
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		21		
Iron	ppm	ASTM D5185m	>90	9	8	8
Chromium	ppm	ASTM D5185m	>5	<1	<1	0
Nickel	ppm	ASTM D5185m	>5	0	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	2	<1	<1
Lead	ppm	ASTM D5185m	>12	<1	2	4
Copper	ppm	ASTM D5185m	>30	1	6	2
Tin	ppm	ASTM D5185m	>9	<1	2	0
Antimony	ppm	ASTM D5185m			0	212
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	A 0	52	45
Calcium	ppm	ASTM D5185m		0	32	4
Phosphorus	ppm	ASTM D5185m		220	58	35
Zinc	ppm	ASTM D5185m		0	3	3
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	69	1	3
Sodium	ppm	ASTM D5185m		0	4	2
Potassium	ppm	ASTM D5185m	>20	2	2	0
Water	%	ASTM D6304	>.1	0.008	0.023	△ 0.125
ppm Water	ppm	ASTM D6304	>1000	85	230	<u> </u>
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	60734		576
Particles >6µm		ASTM D7647	>1300	12419		314
Particles >14µm		ASTM D7647	>160	133		53
Particles >21µm		ASTM D7647	>40	20		18
Particles >38µm		ASTM D7647	>10	1		2

ASTM D7647 >3

mg KOH/g ASTM D8045 0.25

0

ISO 4406 (c) >19/17/14 **23/21/14**

Particles >71µm

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

16/15/13



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (251)452-6335

T: