

PROBLEM SUMMARY

Sample Rating Trend

ISO

X


Area TM 11 Machine Id TM 11 WF


TM 11 WEST SIDE DRYER FAN PUMP


Component **Pump** Fluid

ROYAL PURPLE SYNFILM 150 (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | |
|--------------------------|----------------------|----------------------|---------------|----------|--|--|--|
| Sample Status | | SEVERE | SEVERE | MARGINAL | | | |
| Particles >4µm | ASTM D7647 >5000 | 163217 | 1 7897 | 461 | | | |
| Particles >6µm | ASTM D7647 >1300 | 52133 | 1512 | 251 | | | |
| Particles >14µm | ASTM D7647 >160 | 325 | 1 06 | 42 | | | |
| Particles >21µm | ASTM D7647 >40 | 7 6 | A 30 | 14 | | | |
| Oil Cleanliness | ISO 4406 (c) >19/17/ | 14 0 25/23/16 | 0 20/18/14 | 16/15/13 | | | |

Customer Id: KIMMOBTM11 Sample No.: RP0038094 Lab Number: 06074731 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Filter | | | ? | We recommend you service the filters on this component if applicable. |

HISTORICAL DIAGNOSIS

08 Jun 2017 Diag: Doug Bogart





We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



21 Apr 2011 Diag: Jonathan Hester

WAIER



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system is acceptable. The condition of oil is suitable for further service.



18 Mar 2011 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. The amount and size of particulates present in the system is acceptable. The condition of oil is suitable for further service.






OIL ANALYSIS REPORT

Sample Rating Trend

Area TM 11



Pump





ROYAL PURPLE SYNFILM 150 (--- GAL)

| NOSIS | |
|-------|--|
| | |

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

▲ Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

| | | Jan 2011 | Mar2011 A | pr2011 Jun2017 | Jan2024 | |
|---------------|-------|-------------|------------|----------------|-------------|-------------|
| SAMPLE INFORM | ATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | RP0038094 | RP185452 | RP69311 |
| Sample Date | | Client Info | | 29 Jan 2024 | 08 Jun 2017 | 21 Apr 2011 |
| Machine Age | mths | Client Info | | 0 | 0 | 0 |
| Oil Age | mths | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | SEVERE | SEVERE | MARGINAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|---------|----------|----------|
| PQ | | ASTM D8184 | | 51 | | |
| Iron | ppm | ASTM D5185m | >90 | 27 | 1 | 6 |
| Chromium | ppm | ASTM D5185m | >5 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >5 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >3 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m | >7 | 2 | 0 | <1 |
| Lead | ppm | ASTM D5185m | >12 | 5 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >30 | 4 | <1 | <1 |
| Tin | ppm | ASTM D5185m | >9 | <1 | 1 | 0 |
| Antimony | ppm | ASTM D5185m | | | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | <1 |

| ADDITIVES | | memou | IIIIII/Dase | Current | HISTOLAL | HISTOLYZ |
|------------|-----|-------------|-------------|-------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | <1 | <1 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 90 | 0 | 60 | 74 |
| Calcium | ppm | ASTM D5185m | | 0 | 0 | 5 |
| Phosphorus | ppm | ASTM D5185m | | 233 | 50 | 2 |
| Zinc | ppm | ASTM D5185m | | ▲ 34 | 2 | 2 |
| | | | | | | |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|---------|----------|--------------|
| Silicon | ppm | ASTM D5185m | >60 | 16 | 17 | 3 |
| Sodium | ppm | ASTM D5185m | | 0 | 3 | <1 |
| Potassium | ppm | ASTM D5185m | >20 | 2 | 1 | 4 |
| Water | % | ASTM D6304 | >.1 | 0.007 | 0.028 | ▲ 0.083 |
| ppm Water | ppm | ASTM D6304 | >1000 | 72 | 280 | ▲ 830 |

| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|----------|-------------|----------|
| Particles >4µm | ASTM D7647 | >5000 | 163217 | 1897 | 461 |
| Particles >6µm | ASTM D7647 | >1300 | 52133 | 1512 | 251 |
| Particles >14μm | ASTM D7647 | >160 | 325 | <u> </u> | 42 |
| Particles >21µm | ASTM D7647 | >40 | 76 | △ 30 | 14 |
| Particles >38µm | ASTM D7647 | >10 | 3 | 1 3 | 2 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 3 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | 25/23/16 | 20/18/14 | 16/15/13 |

Acid Number (AN)

FLUID DEGRADATION

mg KOH/g ASTM D8045 0.25

0.377

0.517

Contact/Location: LARRY WEAVER - KIMMOBTM11



OIL ANALYSIS REPORT

