


PROBLEM SUMMARY


Area
TM 11
Machine Id
TM 11 WIRE TURNING ROLL REDUCER
Component
Gearbox
Fluid
GEAR OIL ISO 220 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

Particle Trend



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ATTENTION	SEVERE
Particles >4µm	ASTM D7647	>20000	142109	26451	71404
Particles >6µm	ASTM D7647	>5000	41621	881	8010
Particles >14µm	ASTM D7647	>640	1895	21	52
Particles >21µm	ASTM D7647	>160	390	5	4
Oil Cleanliness	ISO 4406 (c)	>21/19/16	24/23/18	22/17/12	23/20/13

Customer Id: KIMMOBTM11
Sample No.: RP0037980
Lab Number: 06074734
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

08 Aug 2023 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



05 May 2023 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Mar 2022 Diag: Doug Bogart

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
TM 11
 Machine Id
TM 11 WIRE TURNING ROLL REDUCER
 Component
Gearbox
 Fluid
GEAR OIL ISO 220 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP0037980	RP0034369	RP0023577
Sample Date	Client Info		29 Jan 2024	08 Aug 2023	05 May 2023
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ATTENTION	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		26	22	14
Iron	ppm	ASTM D5185m >200	104	90	86
Chromium	ppm	ASTM D5185m >15	<1	<1	0
Nickel	ppm	ASTM D5185m >15	<1	0	0
Titanium	ppm	ASTM D5185m	<1	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	12	10	11
Lead	ppm	ASTM D5185m >100	<1	0	0
Copper	ppm	ASTM D5185m >200	1	<1	<1
Tin	ppm	ASTM D5185m >25	0	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 50	14	15	14
Barium	ppm	ASTM D5185m 15	0	19	0
Molybdenum	ppm	ASTM D5185m 15	<1	<1	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 50	0	0	0
Calcium	ppm	ASTM D5185m 50	1	54	0
Phosphorus	ppm	ASTM D5185m 350	193	258	262
Zinc	ppm	ASTM D5185m 100	3	50	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	0	2	<1
Sodium	ppm	ASTM D5185m	0	3	2
Potassium	ppm	ASTM D5185m >20	2	<1	0
Water	%	ASTM D6304 >0.2	0.013	0.013	0.00
ppm Water	ppm	ASTM D6304 >2000	134	139.1	0.00






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	142109	26451	71404
Particles >6µm	ASTM D7647	>5000	41621	881	8010
Particles >14µm	ASTM D7647	>640	1895	21	52
Particles >21µm	ASTM D7647	>160	390	5	4
Particles >38µm	ASTM D7647	>40	13	0	1
Particles >71µm	ASTM D7647	>10	1	0	1
Oil Cleanliness	ISO 4406 (c)	>21/19/16	24/23/18	22/17/12	23/20/13

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	1.55	1.47	1.49

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	218	221

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0037980 **Received** : 30 Jan 2024
Lab Number : 06074734 **Diagnosed** : 01 Feb 2024
Unique Number : 10856825 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: PQ, PrtCount)

Kimberly-Clark - Mobile - TM 11
 200 BAYBRIDGE RD
 MOBILE, AL
 US 36610
 Contact: LARRY WEAVER
 Larry.D.Weaver@kcc.com
 T:
 F: (251)452-6335

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)