


OIL ANALYSIS REPORT

ÜLTRA COOLANT INGERSOLL RAND CBV433741 - DAVE SINCLAIR LINCOLN

Component







Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			0ct2023	Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06074866	UCH05978375	
Sample Date		Client Info		22 Jan 2024	04 Oct 2023	
Machine Age	hrs	Client Info		24697	23579	
Oil Age	hrs	Client Info		6134	5016	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		0	<1	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	<1	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	0	<1	
Tin	ppm	ASTM D5185m	>15	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	500	395	394	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	0	2	4	
Calcium	ppm	ASTM D5185m	0	16	15	
Phosphorus	ppm	ASTM D5185m	20	0	2	
Zinc	ppm	ASTM D5185m	0	29	31	
Sulfur	ppm	ASTM D5185m	200	431	406	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	2	
Sodium	ppm	ASTM D5185m		97	85	
Potassium	ppm	ASTM D5185m	>20	3	2	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.27	0.31	



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: UCH06074866 : 06074866 : 10856957 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 30 Jan 2024 Recieved Diagnosed : 01 Feb 2024

Diagnostician

: Don Baldridge

Contact: RACHEL VON HATTEN rvonhatten@jhf.com

JOHN HENRY FOSTER COMPANY

4700 LEBOURGET STREET

T: (314)593-1267 F: (314)874-0965

SAINT LOUIS, MO

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) US 63134