

CS1709A-1

# **OIL ANALYSIS REPORT**

#### Sample Rating Trend







## Component Roller Bearing

**ROYAL PURPLE SYNFILM 68 (--- GAL)** 

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0840353		
Sample Date		Client Info		16 Jan 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	<1		
Lead	ppm	ASTM D5185m	>20	<1		
Copper	ppm	ASTM D5185m	>20	0		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	52		
Calcium	ppm	ASTM D5185m		3		
Phosphorus	ppm	ASTM D5185m		1		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		18781		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1		
Sodium	ppm	ASTM D5185m		19		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.25	0.37		



# **OIL ANALYSIS REPORT**

VISUAL





			method	limit/base	current		history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
6/24	Appearance	scalar	*Visual	NORML	NORML		
Jan16/24	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>2	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER			limit/booo		biotomut	biotory ()
			method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	68	68.1		
	SAMPLE IMAGE	ES	method	limit/base	current	history1	history2
Jan16/24	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta			Jan16/24	Acid Number		
	Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta			Jan 16/24	Acid Number		
	Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta			Jan 16/24			
	Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta			Jan 16/24			
	Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta			Jan 16/24			
	Non-ferrous Meta Non-ferrous Meta			10.10 gq ymwer gg ymwer gg ymwer ymau ga ymwer ymau ymau ymau ymau ymau ymau ymau ymau			
	Non-ferrous Meta Non-ferrous Meta			Paul (1974) Paul (	Base		
tory No. mber Number ackage	Non-ferrous Meta Non-ferrous Meta	501 Madia Recieved Diagnost	son Ave., Ca d : 30 ed : 01 ician : Do	(0,40) (0	Base base base base		

To discuss this sample report \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Ĕ

F: