


# **OIL ANALYSIS REPORT**



# BRCM03BE (S/N 6ZJ00395)

Component **Biogas Engine** 

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (150 GAL)



Sample Rating Trend



### DIAGNOSIS

#### Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

#### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal.


#### **Fluid Condition**

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

ENGINE OIL 40 (1	50 GAL)	v2022 Jan20	23 Mar2023 May2023	Jul2023 Sep2023 Nov2023	Dec2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0760890	WC0760892	WC0760907
Sample Date		Client Info		26 Jan 2024	19 Jan 2024	08 Jan 2024
Machine Age	hrs	Client Info		91194	91032	90807
Oil Age	hrs	Client Info		314	152	427
Oil Changed		Client Info		Not Changd	Not Changd	Not Chango
Sample Status				SEVERE	NORMAL	SEVERE
CONTAMINATIO	N	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	5	3	<1
Chromium	ppm	ASTM D5185m	>4	<1	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>6	2	2	2
Lead	ppm	ASTM D5185m	>9	<1	1	2
Copper	ppm	ASTM D5185m	>6	2	1	1
Tin	ppm	ASTM D5185m	>4	4	3	5
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		22	18	14
Barium	ppm	ASTM D5185m		1	0	0
Molybdenum	ppm	ASTM D5185m		13	11	9
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		65	49	45
Calcium	ppm	ASTM D5185m		2188	1771	1842
Phosphorus	ppm	ASTM D5185m		441	341	293
Zinc	ppm	ASTM D5185m		530	399	415
Sulfur	ppm	ASTM D5185m		2848	1915	2004
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	<b>216</b>	116	231
Sodium	ppm	ASTM D5185m		0	2	13
Potassium	ppm	ASTM D5185m	>20	2	0	<1
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	5.9	5.6	6.4
INILIALIOII			00	4= 0	10.1	19.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	17.6	16.4	19.0
		*ASTM D7415 method	>30 limit/base		16.4 history1	
Sulfation						
Sulfation FLUID DEGRADA	ATION	method *ASTM D7414	limit/base	current	history1	history2




## **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


2 00		1					
2.50 - Base 1.50 - Base 0.50 - C	A	1	۸.	٨	1		A A
1.00 Base	1	1	/\	7	1	7	$\Lambda \Lambda$
0.50	v . 1					V	

I LOID I NOI LI	TILO	memou	IIIIII/Dase	Current	HISTOLAL	HISTOLYZ
Visc @ 100°C	cSt	ASTM D445	13.4	12.7	12.5	13.0
GRAPHS						
Iron (nnm)				Load (nnm)		














0							
11000	ormal						
4					AA		
-	\ A	Λ.		_/	M	~ /	1 -
-	$\sim$	N	$\Delta$	~	1		~
)				Jul25/23	19/23	Nov6/23	Dec12/23















Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : MOB 2

: WC0760890 : 06074982 : 10857073

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 30 Jan 2024 Recieved : 01 Feb 2024 Diagnosed

Diagnostician : Sean Felton

**EDL NA Recips-Brown County** BROWN COUNTY POWER STATION, 9427 BEYERS RD

GEORGETOWN, OH US 45121

Contact: MITCHELL BUTLER Mitchell.Butler@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: