

# **OIL ANALYSIS REPORT**



**NORMAL** 



# **Utilities** #3 Atlas Copco

**Reservoir Reciprocating Compressor** 

**ATLAS COPCO ROTO Z FLUID (10 GAL)** 

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		3m2018 Dec2	018 Oct2019 Oct2020	Jul2021 Apr2022 Jan2023	0ct2023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0886188	WC0816909	WC0757603
Sample Date		Client Info		24 Jan 2024	30 Oct 2023	26 Jul 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	ATTENTION
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
Lead	ppm	ASTM D5185m	>25	0	<1	0
Copper	ppm	ASTM D5185m	>50	<1	7	0
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	<1	1
Calcium	ppm	ASTM D5185m		0	<1	2
Phosphorus	ppm	ASTM D5185m		471	487	456
Zinc	ppm	ASTM D5185m		0	<1	10
Sulfur	ppm	ASTM D5185m		633	747	865
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	7656	<b>▲</b> 129021	<b>13140</b>
Particles >6µm		ASTM D7647	>2500	1204	<u> 14461</u>	324
Particles >14μm		ASTM D7647	>320	185	90	12
Particles >21μm		ASTM D7647	>80	55	33	3
Particles >38μm		ASTM D7647	>20	5	2	0
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	20/17/15	<u>4</u> 24/21/14	<b>2</b> 1/16/11
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045

0.35



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No.

Lab Number **Unique Number** 

: WC0886188 : 06075715 : 10857806

Recieved : 31 Jan 2024 Diagnosed Diagnostician

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: 01 Feb 2024 : Don Baldridge

Test Package : IND 2 ( Additional Tests: PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

**INGREDION INC** 

WINSTON SALEM PLANT, 4501 OVERDALE ROAD WINSTON SALEM, NC

US 27107

Contact: MATTHEW KING matthew.king@ingredion.com

T: F: (336)785-8809

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: MATTHEW KING - CORWIN