


PROBLEM SUMMARY

[BATCH 6] RECLAIMED

Component


Refrigeration Compressor


USPI ALT-68 SC (--- GAL)






COMPONENT CONDITION SUMMARY







RECOMMENDATION

This is a baseline read-out on the submitted sample. We were unable to perform a particle count due to a high concentration of particles present in this sample. BATCH 6

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	ABNORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>8	971	0	0		
Water	%	ASTM D6304	>0.01	△ 0.148	0.003	0.003		
ppm Water	ppm	ASTM D6304	>100	<u> </u>	26	30.2		
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	△ 0.293	0.014	0.014		
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	NONE		
Emulsified Water	scalar	*Visual	>0.01	0.2%	NEG	NEG		

Customer Id: KRANEWUSP Sample No.: USP0005427 Lab Number: 06075837 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

26 Dec 2023 Diag: Doug Bogart





This is a baseline read-out on the submitted sample. 5TH BATCH There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



19 Jun 2023 Diag: Doug Bogart

ISO



This is a baseline read-out on the submitted sample. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



25 Apr 2023 Diag: Doug Bogart

150



This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

[BATCH 6] RECLAIMED

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. We were unable to perform a particle count due to a high concentration of particles present in this sample. BATCH 6

Wear

The iron level is severe.

Contamination

Appearance is milky. There is a moderate concentration of water present in the oil. There is a high amount of visible silt present in the sample.

▲ Fluid Condition

The AN level is above the recommended limit. Confirmed.

		Apr202	3 Jun2023	Dec2023 Ja	in2024	
SAMPLE INFORM	/ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0005427	USP0004696	USP244072
Sample Date		Client Info		30 Jan 2024	26 Dec 2023	19 Jun 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	971	0	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	0
Lead	ppm	ASTM D5185m	>2	1	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		4	0	0
Magnesium	ppm	ASTM D5185m		2	0	0
Calcium	ppm	ASTM D5185m		2	0	0
Phosphorus	ppm	ASTM D5185m		<1	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	9	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4	<1	<1
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	2	0	0
Water	%	ASTM D6304	>0.01	<u> </u>	0.003	0.003
ppm Water	ppm	ASTM D6304	>100	1484	26	30.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000		<u>\$\times\$ 25948</u>	<u>44163</u>
Particles >6µm		ASTM D7647	>1300		▲ 5056	▲ 11697
Particles >14µm		ASTM D7647	>320		127	430
Particles >21µm		ASTM D7647	>80		15	39
Particles >38µm		ASTM D7647	>20		1	0
Particles >71µm		ASTM D7647	>4		0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/15		<u>^</u> 22/20/14	<u>\$\rightarrow\$ 23/21/16</u>
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	ma 1/011/a	ACTM DOZA	0.005	A 0.202	0.014	0.014

Acid Number (AN)

mg KOH/g ASTM D974 0.005


0.293

0.014

0.014



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package

: 06075837

: USP0005427 : 10857928 : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 31 Jan 2024 Diagnosed : 06 Feb 2024

Diagnostician : Doug Bogart KraftHeinz - Newberry - Plant 8335 3704 LOUIS RICH DR NEWBERRY, SC

US 29108

Contact:

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)