


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# FRICK C-6 RWBII 316E (S/N WD472YFMPT0GC03)

**Refrigeration Compressor** 

FRICK COMPRESSOR OIL #9 (140 GAL)

	$I \wedge I$	$\sim N$	-	CI.	ю
D	VA\	OIL.	$\sim$	O	o

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Oct2017	Dec2019 Apr2021	Nov2021 May2022 J	lun2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0898026	WC0818865	WC0746964
Sample Date		Client Info		26 Jan 2024	05 Jun 2023	01 Dec 2022
Machine Age	hrs	Client Info		72835	70295	70295
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	8	7	22
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		<1	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	<1
Lead	ppm	ASTM D5185m	>2	<1	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		1	<1	0
Calcium	ppm	ASTM D5185m		7	2	0
Phosphorus	ppm	ASTM D5185m		0	0	23
Zinc	ppm	ASTM D5185m		0	4	3
Sulfur	ppm	ASTM D5185m		52	39	0
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.01	0.005	0.001	0.005
ppm Water	ppm	ASTM D6304	>100	56	10.1	59.5
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A	1/0111	A OTH A DOT		0.044	0.000	0.000

0.014

Acid Number (AN)


mg KOH/g ASTM D974


0.022


0.026



# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

I LOID I HOI LITT	ILO					
Visc @ 40°C	cSt	ASTM D445	64.0	74.6	74.4	73.8

SAMPLE IMAGES	
---------------	--


Color


**Bottom** 




















Laboratory Sample No. Lab Number : 06075904 Unique Number : 10857995

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: WC0898026

Received **Tested** Diagnosed

: 01 Feb 2024

: 02 Feb 2024 - Don Baldridge

: 31 Jan 2024

**PIGGLY WIGGLY** 

2400 TERRELL WOOTEN DR BESSEMER, AL US 35020

Contact: MYRON HALL

Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F:

T: (205)767-6343