

OIL ANALYSIS REPORT

Area AIR COMPRESSOR AIRCOMP-021

Component Air Compressor Fluid {not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sample Rating Trend




NORMAL

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0855697		
Sample Date		Client Info		25 Jan 2024		
Machine Age	hrs	Client Info		2603		
Oil Age	hrs	Client Info		2603		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	0		
Chromium	ppm	ASTM D5185m	>15	0		
Nickel	ppm	ASTM D5185m	>6	<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>20	<1		
Copper	ppm	ASTM D5185m	>80	0		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		2		
Phosphorus	ppm	ASTM D5185m		34		
Zinc	ppm	ASTM D5185m		12		
Sulfur	ppm	ASTM D5185m		117		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>12	11		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.16		



OIL ANALYSIS REPORT

VISUAL



		VISUAL							
		White Metal	scalar	*Visual	NONE	NONE			
		Yellow Metal	scalar	*Visual	NONE	NONE			
		Precipitate	scalar	*Visual	NONE	NONE			
		Silt	scalar	*Visual	NONE	NONE			
		Debris	scalar	*Visual	NONE	NONE			
		Sand/Dirt	scalar	*Visual	NONE	NONE			
	/24	Appearance	scalar	*Visual	NORML	NORML			
	Jan 25/24	Odor	scalar	*Visual	NORML	NORML			
	7	Emulsified Water							
			scalar	*Visual	>0.1	NEG			
		Free Water	scalar	*Visual		NEG			
		FLUID PROPER	TIES	method	limit/base	current	history1	history2	
		Visc @ 40°C	cSt	ASTM D445		46.5			
		SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
	Jan 25/24	Color					no image	no image	
		Bottom					no image	no image	
	wdd wdd	Non-ferrous Meta	ls		Jan25/24				
		Viscosity @ 40°C			Jan25/24				
	cSt (40°C)	55 50 Abnormal			A 0.20 0.15 0.10 0.10 0.00 0.05 0.05 0.05	Acid Number			
		135 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -			Jan25/24	Jan 25/24		4 5 - -	
Laboratory Sample No Lab Number Unique Num).	: WearCheck USA - 501 Madison Ave., Cary, NC : WC0855697 Recieved : 31 Jan 20 : 06075936 Diagnosed : 02 Feb 20 : 10858027 Diagnostician : Doug Bog : IND 2 ontact Customer Service at 1-800-237-1369.				24 6401 MILLER ROA 124 HUBBARD, O			

Submitted By: STEVEN COLLINS

Page 2 of 2