


OIL ANALYSIS REPORT

DF8 [8144] KAESER 1094 - CARGILL EAST (S/N 1094/3280227)

Compressor





Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
|------------------|----------|-------------|------------|-------------|-------------|-------------|
| Sample Number | | Client Info | | UCH06075946 | UCH05954134 | UCH05742688 |
| Sample Date | | Client Info | | 11 Jan 2024 | 06 Sep 2023 | 09 Jan 2023 |
| Machine Age | hrs | Client Info | | 113104 | 110096 | 104887 |
| Oil Age | hrs | Client Info | | 3008 | 5219 | 4996 |
| Oil Changed | | Client Info | | Changed | | Changed |
| Sample Status | | | | NORMAL | NORMAL | NORMAL |
| | | method | limit/base | current | history1 | history2 |
| CONTAMINATION | | | | | | |
| Water | | WC Method | >0.05 | NEG | NEG | NEG |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | 3 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 5 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 1 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | <1 | 4 | <1 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 1 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 0.3 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | <1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | 0 | 1 | 1 | 0 |
| Calcium | ppm | ASTM D5185m | 0.5 | 1 | <1 | 0 |
| Phosphorus | ppm | ASTM D5185m | 536 | 42 | 354 | 190 |
| Zinc | ppm | ASTM D5185m | 0.2 | 0 | 133 | 22 |
| Sulfur | ppm | ASTM D5185m | 649 | 1422 | 1824 | 645 |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | <1 | 1 | <1 |
| Sodium | ppm | ASTM D5185m | | <1 | 4 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 2 | 2 | <1 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.337 | 0.16 | 0.93 | 0.67 |



38

OIL ANALYSIS REPORT




| VISUAL | | method | limit/base | current | history1 | history2 |
|-------------------------|--------|---------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | LIGHT | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| | | | | | | |

| T LOID I TIOT LITT | | | | | | Thistory |
|--------------------|-----|-----------|------|------|------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 42.0 | 42.1 | 43.1 | 43.6 |


SAMPLE IMAGES


Color


Bottom


















Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: UCH06075946 : 06075946

: 10858037 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 31 Jan 2024 Diagnosed : 02 Feb 2024

Diagnostician : Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DELTA INDUSTRIES - CEDAR RAPIDS

6540 4TH ST SW CEDAR RAPIDS, IA US 52404

Contact: MICHAEL FERRIS wearcheck@deltaind.net

T: (319)862-2500

F: (319)862-2501

Contact/Location: MICHAEL FERRIS - UCDELCED