


OIL ANALYSIS REPORT

EXTRUDER EXTRUDER-051

Component

Gear Extruder

LUBRICATION ENG DUOLEC 1605 GEAR OIL 220 (18 GAL)





DIAGNOSIS
Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

•	,			Jan2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0849056		
Sample Date		Client Info		24 Jan 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	22		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>10	<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>100	1		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		30		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		2		
Phosphorus	ppm	ASTM D5185m		461		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		6206		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.92		



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No.

Lab Number **Unique Number**

Test Package : IND 2

(2 0 0 220

180

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0849056 : 06075997 : 10858088

Recieved Diagnosed

: 31 Jan 2024 : 02 Feb 2024 Diagnostician : Doug Bogart

£ 0.6 칕 0.4

> US 97032 Contact: DAVID ELLIS DAVID.ELLIS@PRINSCO.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PRINSCO - HUBBARD

6401 MILLER ROAD

HUBBARD, OR

T: F: