

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

KAESER AS 20 100917.00001 - 1617 - ROLLED ALLOYS

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jan2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0893732		
Sample Date		Client Info		24 Jan 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	26		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		15		
Sulfur	ppm	ASTM D5185m		15936		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		17		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37		




42

Ē

Abnormal 40 38 Jan24/24

OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE		
*****	Yellow Metal		*Visual	NONE	NONE		
	Precipitate		*Visual	NONE	NONE		
	Silt		*Visual	NONE	NONE		
	Debris		*Visual	NONE	NONE		
	Sand/Dirt		*Visual	NONE	NONE		
4/24	Appearance		*Visual	NORML	NORML		
Jan 24/24	Odor		*Visual	NORML	NORML		
	Emulsified Water		*Visual	>0.05	NEG		
	Free Water		*Visual		NEG		
	FLUID PROPERT			limit/baga		history1	biotory?
	Visc @ 40°C		method ASTM D445	limit/base 46	current 44.3	history1	history2
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Jan24/24 +	Color					no image	no image
	Bottom					no image	no image
	Ferrous Alloys			Jan24/24			
	Viscosity @ 40°C				Acid Number		
	50 - Abnormal			(0.50 0.40 0.30 0.20 Vmpt 0.20 0.10	Base		
	50 +						
	ま 45 •						
	40 - Abnormal			- N.20	1		
	35			0.00	-		
	Jan 24/24			Jan 24/24	Jan 24/24		
Laboratory Sample No. Lab Number	WearCheck USA - 501 Madison Ave., Cary, NC 275 WC0893732 Recieved : 01 Feb 2024 06076983 Diagnosed : 02 Feb 2024 10859074 Diagnostician : Don Baldridge IND 2 Intact Customer Service at 1-800-237-1369. outside of the ISO 17025 scope of accreditation.						