

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Byron Center CAT 1 BYCM01BE

Biogas Engine

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Moor

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		72023 Marzo	23 Mily2023 Uni2023	002023 NOV2023	30112027	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0877031	WC0640335	WC0640336
Sample Date		Client Info		30 Jan 2024	22 Jan 2024	16 Jan 2024
Machine Age	hrs	Client Info		85572	85380	0
Oil Age	hrs	Client Info		310	118	530
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method		NEG	NEG	NEG
Glycol		WC Method	70.1	NEG	NEG	NEG
WEAR METALS			limit/base			
		method		current	history1	history2
Iron	ppm	ASTM D5185m	>15	<1	1	0
Chromium	ppm	ASTM D5185m		0	<1	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m	_	0	<1	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m		2	1	2
Lead	ppm	ASTM D5185m	>9	<1	<1	0
Copper	ppm	ASTM D5185m		<1	<1	2
Tin	ppm	ASTM D5185m	>4	2	1	3
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	1	0
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		<1	2	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		9	7	9
Calcium	ppm	ASTM D5185m		1779	1761	1827
Phosphorus	ppm	ASTM D5185m		269	266	277
Zinc	ppm	ASTM D5185m		330	318	348
Sulfur	ppm	ASTM D5185m		2433	2427	2592
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	118	73	148
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	2	0
INIEDA DED		method	limit/base	current	history1	history2
INFRA-RED		metrioa				
Soot %	%	*ASTM D7844		0	0	0
	% Abs/cm		>20	0 6.0	0 5.5	0 6.0
Soot %		*ASTM D7844	>20 >30			
Soot % Nitration	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624		6.0	5.5	6.0
Soot % Nitration Sulfation FLUID DEGRADA	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624 *ASTM D7415	>30 limit/base	6.0 21.9 current	5.5 18.2 history1	6.0 22.5 history2
Soot % Nitration Sulfation FLUID DEGRADA Oxidation	Abs/cm Abs/.1mm ATION Abs/.1mm	*ASTM D7844 *ASTM D7624 *ASTM D7415 method *ASTM D7414	>30 limit/base >25	6.0 21.9 current 14.0	5.5 18.2 history1 10.2	6.0 22.5 history2 14.1
Soot % Nitration Sulfation FLUID DEGRADA	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624 *ASTM D7415 method *ASTM D7414	>30 limit/base	6.0 21.9 current	5.5 18.2 history1	6.0 22.5 history2



OIL ANALYSIS REPORT










VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPER	THES	method	iimii/base		nistory i	nistory∠
Visc @ 100°C	cSt	ASTM D445	13.4	13.4	13.3	13.6





GRAPHS





















Certificate L2367

Laboratory Sample No. Lab Number : 06077053 Unique Number : 10859144

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0877031

Received **Tested** : 02 Feb 2024 - Sean Felton Diagnosed

:01 Feb 2024

: 02 Feb 2024

EDL NA Recips-Byron Center Byron Center Powerstation, 10310 South Kent Road

Byron Center, MI US 49315 Contact: Jake Ripke

Test Package : MOB 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Jake.Ripke@edlenergy.com T:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: