


# **OIL ANALYSIS REPORT**

## Sample Rating Trend







# Machine Id HBKM02BE Component Biogas Engine

Biogas Engine

SHELL MYSELLA S5 S (48 GAL)

### DIAGNOSIS

#### Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Top Up Amount: 30 GAL )

#### Wear

All component wear rates are normal.

#### Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.


#### **Fluid Condition**


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.


(48 GAL)		r2023 May20	23 Jun2023 Aug2023	Sep2023 Oct2023 Nov2023	Jan2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0775463	WC0775461	WC0775458
Sample Date		Client Info		29 Jan 2024	22 Jan 2024	15 Jan 2024
Machine Age	hrs	Client Info		104441	104278	104112
Oil Age	hrs	Client Info		874	711	545
Oil Changed		Client Info		Oil Added	N/A	Oil Added
Sample Status				SEVERE	ABNORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	5	5	6
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>6	4	4	3
Lead	ppm	ASTM D5185m	>9	<1	<1	0
Copper	ppm	ASTM D5185m	>6	2	2	2
Tin	ppm	ASTM D5185m	>4	6	5	4
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	4	5
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		5	6	7
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		41	40	66
Calcium	ppm	ASTM D5185m		1543	1619	1606
Phosphorus	ppm	ASTM D5185m	300	345	362	380
Zinc	ppm	ASTM D5185m		444	446	469
Sulfur	ppm	ASTM D5185m		3221	4054	3382
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	<b>231</b>	<u> </u>	162
Sodium	ppm	ASTM D5185m		2	0	2
Potassium	ppm	ASTM D5185m	>20	0	2	0
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0	0
300t /6		*A OTA A D700 4	<b>&gt;20</b>	5.5	5.3	5.1
	Abs/cm	*ASTM D7624	>20	0.0	0.0	0.1
Nitration	Abs/cm Abs/.1mm	*ASTM D7624	>30	24.9	23.9	22.5
Nitration	Abs/.1mm					22.5
Nitration Sulfation FLUID DEGRAD	Abs/.1mm	*ASTM D7415	>30	24.9	23.9	22.5
Nitration Sulfation	Abs/.1mm	*ASTM D7415  method  *ASTM D7414	>30 limit/base	24.9 current	23.9 history1	22.5 history2




## **OIL ANALYSIS REPORT**












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.8	13.7	13.6


Seve	ere						
Abn	ormal						
T							
					- 4	1	1
~	~	~	~	~	1	1	1
Apr11/23	May16/23	Jun19/23	~	Sep18/23-	Oct23/23	Nov27/23	Jan3/24 - \
























Certificate L2367

Laboratory Sample No. Lab Number Test Package : MOB 2

**Unique Number** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0775463 : 06077056 : 10859147

Recieved Diagnosed Diagnostician

: 01 Feb 2024 : 02 Feb 2024 : Sean Felton

**EDL NA Recips-Honeybrook** 

Honey Brook Powerstation, 481 S. Churchtown Road Narvon, PA

US 17555-9574 Contact: Christian Adames

Christian.Adames@edlenergy.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: