


PROBLEM SUMMARY

Sample Rating Trend



WEAR




Machine Id
BT-FOR-A3 (S/N TANK FT3 AGITATOR)

Component
Gearbox


Fluid
SHELL OMALA S2 GX 220 (--- GAL)

COMPONENT CONDITION SUMMARY


Particle Trend



PQ



Ferrous Alloys



RECOMMENDATION

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | SEVERE | NORMAL |
|-----------------|-----|------------------------|------------|----------|----------|
| PQ | | ASTM D8184 | ▲ 153 | 36 | 11 |
| Iron | ppm | ASTM D5185m >200 | ▲ 114 | 59 | 50 |
| Particles >4µm | | ASTM D7647 >20000 | ● 184263 | 164595 | 8042 |
| Particles >6µm | | ASTM D7647 >5000 | ● 136492 | 72877 | 757 |
| Particles >14µm | | ASTM D7647 >640 | ● 10385 | ▲ 1139 | 25 |
| Particles >21µm | | ASTM D7647 >160 | ▲ 381 | 60 | 7 |
| Oil Cleanliness | | ISO 4406 (c) >21/19/16 | ● 25/24/21 | 25/23/17 | 20/17/12 |

Customer Id: MOMBAY
Sample No.: PLS0000809
Lab Number: 06077615
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

25 Oct 2023 Diag: Mike Johnson

ISO



Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use provided that contamination is brought under control.

view report



09 Aug 2023 Diag: Mike Johnson

NORMAL



No action required at this time. Resample at next normal interval. Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Filtration can help to extend machine life. Fluid health indicators are acceptable for continued use.

view report



01 May 2023 Diag: Mike Johnson

NORMAL




No action required at this time. Resample at next normal interval. Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Filtration can help to extend machine life. Fluid health indicators are acceptable for continued use.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
BT-FOR-A3 (S/N TANK FT3 AGITATOR)

Component

Gearbox

Fluid

SHELL OMALA S2 GX 220 (--- GAL)

DIAGNOSIS

Recommendation

Filter oil if possible using B6=75 filter media or better. Investigate sample procedures and possible sources of contamination. If oil has been exposed due to broken seals or open breathers, consider changing oil. Resample at next normal interval.

Wear

Iron wear particles are elevated from previous samples. This could indicate accelerated wear

Contamination

Particle contamination is elevated. Filtration can help extend machine life.

Fluid Condition

Fluid health is acceptable for continued use provided that contamination is brought under control.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | PLS0000809 | PLS0000780 | PLS0000564 |
| Sample Date | Client Info | | 31 Jan 2024 | 25 Oct 2023 | 09 Aug 2023 |
| Machine Age | mths | Client Info | 3 | 0 | 0 |
| Oil Age | mths | Client Info | 0 | 1 | 0 |
| Oil Changed | Client Info | | N/A | Changed | N/A |
| Sample Status | | | SEVERE | SEVERE | NORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|------------|------------------|--------------|----------|----------|
| PQ | ASTM D8184 | | ▲ 153 | 36 | 11 |
| Iron | ppm | ASTM D5185m >200 | ▲ 114 | 59 | 50 |
| Chromium | ppm | ASTM D5185m >15 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >15 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | <1 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >25 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m >100 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m >200 | 0 | 0 | <1 |
| Tin | ppm | ASTM D5185m >25 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 6.2 | 0 | <1 | 1 |
| Barium | ppm | ASTM D5185m 0.0 | <1 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m 0 | 0 | 0 | <1 |
| Manganese | ppm | ASTM D5185m | 1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m 0 | 2 | 0 | 2 |
| Calcium | ppm | ASTM D5185m 0.0 | 5 | 0 | 3 |
| Phosphorus | ppm | ASTM D5185m 290 | 302 | 193 | 279 |
| Zinc | ppm | ASTM D5185m 3.8 | 15 | 0 | 18 |
| Sulfur | ppm | ASTM D5185m 8167 | 9699 | 8473 | 10595 |






CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | 2 | <1 | 1 |
| Sodium | ppm | ASTM D5185m | 0 | 2 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 0 | 0 | <1 |

INFRA-RED

| | method | limit/base | current | history1 | history2 |
|-----------|---------|-------------|-------------|----------|----------|
| Soot % | % | *ASTM D7844 | 0.1 | 0 | 0 |
| Nitration | Abs/cm | *ASTM D7624 | 3.0 | 3.0 | 2.9 |
| Sulfation | Abs.1mm | *ASTM D7415 | 12.2 | 12.4 | 12.1 |

OIL ANALYSIS REPORT



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000809 **Received** : 01 Feb 2024
Lab Number : 06077615 **Tested** : 02 Feb 2024
Unique Number : 10859706 **Diagnosed** : 09 Feb 2024 - Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|----------|----------|----------|
| Particles >4µm | ASTM D7647 | >20000 | 184263 | 164595 | 8042 |
| Particles >6µm | ASTM D7647 | >5000 | 136492 | 72877 | 757 |
| Particles >14µm | ASTM D7647 | >640 | 10385 | 1139 | 25 |
| Particles >21µm | ASTM D7647 | >160 | 381 | 60 | 7 |
| Particles >38µm | ASTM D7647 | >40 | 2 | 0 | 1 |
| Particles >71µm | ASTM D7647 | >10 | 1 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | 25/24/21 | 25/23/17 | 20/17/12 |

| FLUID DEGRADATION | method | limit/base | current | history1 | history2 |
|-------------------|----------------------|------------|---------|----------|----------|
| Oxidation | Abs/.1mm *ASTM D7414 | | 2.9 | 3.3 | 3.0 |
| Acid Number (AN) | mg KOH/g ASTM D8045 | | 0.60 | 0.58 | 0.60 |

| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|----------------|------------|---------|----------|----------|
| White Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar *Visual | >0.2 | NEG | NEG | NEG |
| Free Water | scalar *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|---------------|------------|---------|----------|----------|
| Visc @ 40°C | cSt ASTM D445 | 220 | 213 | 211 | 212 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

Color



Bottom