

OIL ANALYSIS REPORT

Sample Rating Trend



KAESER DSD 200 9069048 (S/N 1192)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			0ct2023	Jan2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121644	KC111634	
Sample Date		Client Info		11 Jan 2024	05 Oct 2023	
Machine Age	hrs	Client Info		4827	2858	
Oil Age	hrs	Client Info		0	2858	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	5	11	
Lead	ppm	ASTM D5185m	>10	3	<1	
Copper	ppm	ASTM D5185m	>50	2	0	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		2	0	
Magnesium	ppm	ASTM D5185m	90	9	2	
Calcium	ppm	ASTM D5185m	2	1	1	
Phosphorus	ppm	ASTM D5185m		14	26	
Zinc	ppm	ASTM D5185m		0	<1	
CONTAMINANTS	i	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m		6	0	
Potassium	ppm	ASTM D5185m	>20	4	2	
Water	%	ASTM D6304	>0.05	0.005	0.002	
ppm Water	ppm	ASTM D6304	>500	59	24.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6465	2695	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2369	585	
Particles >14μm		ASTM D7647	>80	<u>^</u> 250	33	
Particles >21µm		ASTM D7647	>20	<u>^</u> 65	8	
Particles >38μm		ASTM D7647	>4	2	0	
Particles >71μm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>20/18/15</u>	19/16/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.40	0.41	



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: KC121644 : 06077697 : 10859788 Test Package : IND 2

: 01 Feb 2024 Recieved Diagnosed Diagnostician

: 04 Feb 2024 : Don Baldridge

3250 LINEBAUGH RD XENIA, OH US 45385

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: