


OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
KAESER BS 51 1195473 (S/N 410086)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA006585	KCP50539	KCP33552
Sample Date	Client Info			11 Jan 2024	17 Aug 2022	06 May 2021
Machine Age	hrs	Client Info		49905	40442	40389
Oil Age	hrs	Client Info		0	52	2000
Oil Changed	Client Info			N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	1	2	0
Lead	ppm	ASTM D5185m	>10	2	<1	0
Copper	ppm	ASTM D5185m	>50	4	<1	3
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	1
Barium	ppm	ASTM D5185m	90	14	16	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		2	<1	0
Magnesium	ppm	ASTM D5185m	100	29	56	<1
Calcium	ppm	ASTM D5185m	0	1	2	0
Phosphorus	ppm	ASTM D5185m	0	1	<1	0
Zinc	ppm	ASTM D5185m	0	29	37	33
Sulfur	ppm	ASTM D5185m	23500	19523	18523	18424

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		4	2	0
Potassium	ppm	ASTM D5185m	>20	4	<1	0
Water	%	ASTM D6304	>0.05	0.011	0.013	0.009
ppm Water	ppm	ASTM D6304	>500	112	130.4	96.7

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		11250	3054	4042
Particles >6µm		ASTM D7647	>1300	2539	373	903
Particles >14µm		ASTM D7647	>80	70	9	73
Particles >21µm		ASTM D7647	>20	15	1	22
Particles >38µm		ASTM D7647	>4	0	0	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	21/19/13	19/16/10	17/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.52	0.40	0.579

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	46.4	45.4	45.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006585 **Received** : 01 Feb 2024
Lab Number : 06077708 **Diagnosed** : 04 Feb 2024
Unique Number : 10859799 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

MICRO-MECHANICS
 465 WOODVIEW AVE
 MORGAN HILL, CA
 US 95037
 Contact: C. ALLEN
 callen@micro-mechanics.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)