

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id **7287200 (S/N 1001)** Component

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Jan 2023	Jan 2024		
SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006532	KCP46837	
Sample Date		Client Info		12 Jan 2024	06 Jan 2023	
Machine Age	hrs	Client Info		6701	4924	
Oil Age	hrs	Client Info		0	4924	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	2	0	
Copper	ppm	ASTM D5185m		5	6	
Tin	ppm		>10	1	0	
Vanadium	ppm	ASTM D5185m	210	0	0	
Cadmium	ppm	ASTM D5185m		۰ <1	0	
	ppm		1		-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		2	0	
Magnesium	ppm	ASTM D5185m	100	21	2	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	7	38	
Zinc	ppm	ASTM D5185m	0	30	10	
Sulfur	ppm	ASTM D5185m	23500	18938	21262	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	
Sodium	ppm	ASTM D5185m		7	0	
Potassium	ppm	ASTM D5185m	>20	5	1	
Water	%	ASTM D6304	>0.05	0.016	0.008	
ppm Water	ppm	ASTM D6304	>500	168	84.9	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3984		
Particles >6µm		ASTM D7647	>1300	380		
Particles >14µm		ASTM D7647	>80	30		
Particles >21µm		ASTM D7647	>20	7		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/16/12		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.46	0.41	
		. 10 1 11 000-10		0.10	0.11	




OIL ANALYSIS REPORT









To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

:04 Feb 2024

Diagnostician : Don Baldridge

Certificate L2367

T:

F:

MODESTO, CA US 95351

Contact: JORGE PROAG

JORGE.PROAG@YAHOO.COM