

OIL ANALYSIS REPORT



ISO

Machine Id **8445556 (S/N 1635)**

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar202	3 Apr2023	Oct2023 Ja	n2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010400	KCPA007809	KCPA002746
Sample Date		Client Info		29 Jan 2024	05 Oct 2023	18 Apr 2023
Machine Age	hrs	Client Info		11558	8776	4891
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	2	0	0
Copper	ppm	ASTM D5185m	>50	9	8	2
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	3	52
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		2	0	<1
Magnesium	ppm	ASTM D5185m	100	1	0	68
Calcium	ppm	ASTM D5185m	0	<1	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	1	<1
Zinc	ppm	ASTM D5185m	0	0	5	0
Sulfur	ppm	ASTM D5185m	23500	12451	15181	21900
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		2	<1	6
Potassium	ppm	ASTM D5185m	>20	4	2	2
Water	%	ASTM D6304	>0.05	0.007	0.005	0.018
ppm Water	ppm	ASTM D6304	>500	70	56.3	187.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8743	4950	2507
Particles >6µm		ASTM D7647	>1300	<u> 5241</u>	1102	946
Particles >14µm		ASTM D7647	>80	<u> </u>	33	37
Particles >21µm		ASTM D7647	>20	<u></u> 320	6	3
Particles >38µm		ASTM D7647	>4	<u> </u>	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/20/17	19/17/12	19/17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.34	0.35	0.39



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 06077716 : 10859807

Diagnosed

: 04 Feb 2024

Diagnostician : Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FREMONT, CA US 94539

Contact: D MILLER

d.miller@diamondfoundry.com T:

F:

Contact/Location: D MILLER - DIAFRECA