




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
1041
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KC101480	KC101477	KC100077
Sample Date	Client Info	01 Feb 2024	04 Mar 2023	05 Oct 2021
Machine Age	hrs	Client Info	35443	24461
Oil Age	hrs	Client Info	4880	2014
Oil Changed	Client Info	Not Chngd	Not Chngd	Not Chngd
Sample Status		ABNORMAL	NORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	0	0	0
Chromium ppm	ASTM D5185m >10	0	0	0
Nickel ppm	ASTM D5185m >3	1	0	0
Titanium ppm	ASTM D5185m >3	0	0	0
Silver ppm	ASTM D5185m >2	<1	0	<1
Aluminum ppm	ASTM D5185m >10	<1	0	0
Lead ppm	ASTM D5185m >10	2	0	0
Copper ppm	ASTM D5185m >50	10	8	▲ 54
Tin ppm	ASTM D5185m >10	1	0	0
Antimony ppm	ASTM D5185m	---	---	0
Vanadium ppm	ASTM D5185m	0	0	0
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	0	0	<1
Barium ppm	ASTM D5185m 90	0	5	0
Molybdenum ppm	ASTM D5185m	<1	0	0
Manganese ppm	ASTM D5185m	2	<1	0
Magnesium ppm	ASTM D5185m 90	16	29	0
Calcium ppm	ASTM D5185m 2	1	<1	0
Phosphorus ppm	ASTM D5185m	<1	3	0
Zinc ppm	ASTM D5185m	8	0	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	1	0	0
Sodium ppm	ASTM D5185m	16	1	0
Potassium ppm	ASTM D5185m >20	6	2	0
Water %	ASTM D6304 >0.05	0.008	0.008	0.006
ppm Water	ASTM D6304 >500	83	80.8	68.1






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	5481	1917	9910
Particles >6µm	ASTM D7647 >1300	▲ 2103	595	▲ 2264
Particles >14µm	ASTM D7647 >80	▲ 215	49	80
Particles >21µm	ASTM D7647 >20	▲ 68	11	10
Particles >38µm	ASTM D7647 >4	1	1	1
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 20/18/15	18/16/13	▲ 18/13

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 0.4	0.45	0.40	0.453

OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	43.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC101480 **Received** : 01 Feb 2024
Lab Number : 06077718 **Diagnosed** : 04 Feb 2024
Unique Number : 10859809 **Diagnostician** : Don Baldrige
Test Package : IND 2

NANOGATE
 150 E LONGVIEW AVE
 MANSFIELD, OH
 US 44903
 Contact: MATT BUZARD
 matt.buzard@nanogate.com
 T: (419)521-0191
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)