


OIL ANALYSIS REPORT



ISO

7611291 (S/N 1777) Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2021	Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010681	KCP39857	
Sample Date		Client Info		02 Jan 2024	19 Nov 2021	
Machine Age	hrs	Client Info		3465	996	
Oil Age	hrs	Client Info		0	996	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	2	7	
Lead	ppm	ASTM D5185m	>10	2	0	
Copper	ppm	ASTM D5185m	>50	14	2	
Tin	ppm	ASTM D5185m	>10	1	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	<1	
Manganese	ppm	ASTM D5185m		5	<1	
Magnesium	ppm	ASTM D5185m	100	39	54	
Calcium	ppm	ASTM D5185m	0	1	<1	
Phosphorus	ppm	ASTM D5185m	0	<1	2	
Zinc	ppm	ASTM D5185m	0	25	7	
Sulfur	ppm	ASTM D5185m	23500	19569	16132	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		10	4	
Potassium	ppm	ASTM D5185m	>20	14	26	
Water	%	ASTM D6304	>0.05	0.029	0.019	
ppm Water	ppm	ASTM D6304	>500	297	195.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		13499	4471	
Particles >6µm		ASTM D7647	>1300	4465	1699	
Particles >14μm		ASTM D7647	>80	459	77	
Particles >21μm		ASTM D7647	>20	<u> </u>	14	
Particles >38μm		ASTM D7647	>4	4	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>21/19/16</u>	1 8/13	

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.37 0.326 Contact/Location: Service Manager - UNLWIL



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KCPA010681 : 06077725

: 10859816

Recieved : 01 Feb 2024 Diagnosed Diagnostician : Don Baldridge

: 04 Feb 2024 Test Package : IND 2 (Additional Tests: KF, PrtCount)

WILWOOD, GA

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) US 30757

T: F: