




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
MELT SHOP - HYDRAULIC
 Machine Id
MELT SHOP EAF INLINE HEATER
 Component
Hydraulic System
 Fluid
FIRE-RESISTANT FLUID ISO 46 (5 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The pH level of this fluid is within the acceptable limits at 10.0. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0039210	RP0038550	RP0038018
Sample Date	Client Info	31 Jan 2024	04 Jan 2024	06 Dec 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	0	0
Chromium	ppm	ASTM D5185m >20	0	0
Nickel	ppm	ASTM D5185m >20	<1	0
Titanium	ppm	ASTM D5185m	0	0
Silver	ppm	ASTM D5185m	<1	0
Aluminum	ppm	ASTM D5185m >20	<1	0
Lead	ppm	ASTM D5185m >20	3	0
Copper	ppm	ASTM D5185m >20	2	0
Tin	ppm	ASTM D5185m >20	1	0
Vanadium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	0	0
Barium	ppm	ASTM D5185m 5	0	0
Molybdenum	ppm	ASTM D5185m 5	<1	0
Manganese	ppm	ASTM D5185m	2	0
Magnesium	ppm	ASTM D5185m 5	1	0
Calcium	ppm	ASTM D5185m 50	1	0
Phosphorus	ppm	ASTM D5185m 175	6	0
Zinc	ppm	ASTM D5185m 62	6	0






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	0
Sodium	ppm	ASTM D5185m	2	0
Potassium	ppm	ASTM D5185m >20	4	0
Water	%	ASTM D6304 >55	42.1	42.6
ppm Water	ppm	ASTM D6304 >55000	421000	426000

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	348	1392	313
Particles >6µm	ASTM D7647 >1300	190	758	171
Particles >14µm	ASTM D7647 >160	32	129	29
Particles >21µm	ASTM D7647 >40	11	43	10
Particles >38µm	ASTM D7647 >10	2	7	2
Particles >71µm	ASTM D7647 >3	0	1	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	16/15/12	18/17/14	15/15/12

OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG





FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287	10.0	9.00	9.0
Visc @ 40°C	cSt	ASTM D445	46	52.6	52.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0039210 **Received** : 01 Feb 2024
Lab Number : 06077754 **Tested** : 07 Feb 2024
Unique Number : 10859845 **Diagnosed** : 07 Feb 2024 - Doug Bogart
Test Package : IND 2 (Additional Tests: pH, ReserveAlk)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

OUTOKUMPU STAINLESS USA
 HWY 43 N
 CALVERT, AL
 US 36513
 Contact: MARIO JOHNSON
 Mario.johnson@outokumpu.com
 T: (251)321-4105
 F: x: