


## **OIL ANALYSIS REPORT**



NORMAL



Machine Id
TOTE Component
New (Unused) Oil
Fluid {not provided} (--- GAL)


## Recommendation

This is a baseline read-out on the submitted sample.

				Jan2024		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WCI101249		
Sample Date		Client Info		26 Jan 2024		
Machine Age	mls	Client Info		0		
Oil Age	mls	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method		NEG		
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>5	7		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m	>5	0		
Γitanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>5	0		
Aluminum	ppm	ASTM D5185m	>5	0		
_ead	ppm	ASTM D5185m	>5	0		
Copper	ppm	ASTM D5185m	>5	21		
Fin	ppm	ASTM D5185m	>5	<1		
/anadium	ppm	ASTM D5185m	_	0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		3		
Calcium	ppm	ASTM D5185m		61		
Phosphorus	ppm	ASTM D5185m		359		
Zinc	ppm	ASTM D5185m		417		
Sulfur	ppm	ASTM D5185m		2430		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	2		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual		NEG		
Free Water	scalar	*Visual		NEG		
12:21) Pay: 1	Joalai	VISUAI			CHITCK IVCCK	CON DEAD



## **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number

: 06077907 Unique Number : 10859998

: WCI101249

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved Diagnosed

: 01 Feb 2024 : 05 Feb 2024 Diagnostician : Jonathan Hester

Test Package : IND 1 (Additional Tests: FT-IR, ICP-NewOil, KV100, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**BEARDEN INDUSTRIAL** 

1012 SOUTH HAMILTON STREET DALTON, GA

US 30721

Contact: CHUCK JACSKSON CHUCK@BEARDENSUPPLY.COM

T:

F:

Contact/Location: CHUCK JACSKSON - BEADAL