

OIL ANALYSIS REPORT

SAMPLE INFORMATION method

Sample Rating Trend

WATER

A

history1

MELT SHOP - HYDRAULIC Machine Id MELT SHOP GRINDER LUBE TANK (S/N 15-4000-0770)

Component

Tank Bulk Fluid Tank

FIRE-RESISTANT FLUID ISO 68 (275 QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	ilmit/base	current	nistory i	nistory2
Sample Number		Client Info		RP0039318	RP0038543	RP0038071
Sample Date		Client Info		31 Jan 2024	04 Jan 2024	06 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		18	25	9
Chromium	ppm	ASTM D5185m		0	<1	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		<1	0	0
Lead	ppm	ASTM D5185m		<1	0	0
Copper	ppm	ASTM D5185m		0	<1	1
Tin	ppm	ASTM D5185m		<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррпп					
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	5	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	5	0	0	0
Calcium	ppm	ASTM D5185m	50	0	0	3
Phosphorus	ppm	ASTM D5185m	175	550	597	591
Zinc	ppm	ASTM D5185m	62	0	0	0
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<1	<1	<1
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>55	△ 0.092	△ 0.081	0.003
ppm Water	ppm	ASTM D6304	>55000	930	▲ 811	37
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	<u> </u>	▲ 138274	19227
Particles >6µm		ASTM D7647	>5000	<u> </u>	▲ 33884	1568
Particles >14µm		ASTM D7647	>640	68	299	55
Particles >21µm		ASTM D7647	>160	4	23	13
Particles >38µm		ASTM D7647	>40	0	0	1
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u>4</u> 24/21/13	<u>4</u> 24/22/15	21/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.63	0.63	0.56	0.52
ACIO NUMBER (AN)	my NOTI/ý	70 LINI D0040	0.00	0.03	0.50	0.52




OIL ANALYSIS REPORT




120k -	area area area area area area area area	ım ım					
100k - ****	14	μm					
80k						1111	11 113
60k -							
60k - 40k -							
40k	normal						
ZUK + U	normal						
60k 40k 20k 0k 12/k2qs-	Jun29/21	0ct27/21	Mar22/22	Aug2/22	Jan4/23	May2/23	Sep27/23





Reserve Alkalinity



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	70.64	70.63	70.29
Visc @ 100°C	cSt	ASTM D445	8.6	13.05	12.73	12.75
Viscosity Index (VI)	Scale	ASTM D2270	96	188	182	183
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color				- CO. C.	0.	

GRAPHS Ferrous Alloys Particle Count 491.52 122,88 1,920 480 Non-ferrous Metals 120 Viscosity @ 40°C Acid Number KOH/g) g 6.00

4.00 4.00 2.00

Acid N

: 01 Feb 2024





Laboratory Sample No. Lab Number : 06077908

\$ 61

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : RP0039318

Base

Bottom

Received **Tested**

: 05 Feb 2024 Unique Number : 10859999 Diagnosed : 05 Feb 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KV100, pH, PrtCount, ReserveAlk, VI) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

OUTOKUMPU STAINLESS USA

HWY 43 N CALVERT, AL US 36513

Contact: MARIO JOHNSON Mario.johnson@outokumpu.com

T: (251)321-4105 F: x: